

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

In the matter of the Application of
San Diego Gas & Electric Company
(U 902-E) for a Certificate of Public
Convenience and Necessity for the
Sunrise Powerlink Transmission
Project

Application No. 06-08-010
(Filed August 4, 2006)

**PHASE 2 DIRECT TESTIMONY OF THE
MUSSEY GRADE ROAD ALLIANCE
FIRE ANALYSIS – SAFETY AND ENVIRONMENTAL**

Diane Conklin, Spokesperson
Mussey Grade Road Alliance
P.O. Box 683
Ramona, CA 92065
Telephone: (760) 787-0794
Facsimile: (760) 788- 5479
Email: dj0conklin@earthlink.net

Dated: March 12, 2008

1 **TABLE OF CONTENTS**

2

3 1. INTRODUCTION AND TESTIMONY SUMMARY 1
4 2. THE OCTOBER 2007 FIRESTORM AND ITS IMPLICATIONS..... 2
5 3. COMPARISON OF THE PROPOSED AND ALTERNATIVE ROUTES 31
6 4. SDG&E OUTAGE AND FIRE DATA FOR 2007 37
7 5. MATERIAL FACTUAL DEFICIENCIES AND INACCURACIES IN THE
8 DRAFT EIR/EIS 47
9 6. CRITIQUE OF SDG&E WIND DATA AND ANALYSIS 56

10

11 **APPENDICES AND ATTACHMENTS**

12

13 FILE

CONTENTS

14

15 MGRA_SPL_App2A_2007Fires.pdf	App. 2A – October 2007 fires
16 MGRA_SPL_App2B_SCALFires_C1.pdf	App. 2B – Historical S. Cal PL fires
17 MGRA_SPL_App2C_Alternatives.pdf	App. 2C – Alternatives
18 MGRA_SPL_App2D_SDGE2007.pdf	App. 2D – SDG&E fire data, 2007
19 MGRA_SPL_App2E_EIREIS.pdf	App. 2E – Draft EIR/EIS critique
20 MGRA_SPL_App2F_References.pdf	App. 2F – References
21 MGRA_SPL_App2G_SDGEWinds.pdf	App. 2G – SDG&E wind data
22 MGRA_SPL_App2H_Acronymns.pdf	App. 2H – Acronyms
23 MGRA_SPL_App2I_Press.pdf	App. 2I – Press Accounts, Oct.2007
24	
25 MGRA_SPL_Phase2_Attachments.zip	File2A1_October2007Fires.xls
26	File2A2_October Fire Causes.pdf
27	File2A3_BurnedAreas2003-2007.xls
28	File2B1_SCPerimeterSummary_C1.xls
29	File2B2_SCWeatherSA.xls
30	File2C1_RouteAnalysis_SPLAlt_2.4.xls

1	File2D1_SDGE_Outages_2007.xls
2	File2D2_MGRA DR5-41 SDGE Fire Cause Data 2004-2007.xls
3	File2G1_WindHistory.xls
4	File2G2_SDGE_MGRA49_map.pdf
5	

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 1 of 69

1. INTRODUCTION AND TESTIMONY SUMMARY

Q. Please state your name, address, company and qualifications.

A. My name is Dr. Joseph W. Mitchell. I live at 19412 Kimball Valley Road, Ramona, CA 92065. I am the principal of M-bar Technologies and Consulting, also in Ramona, CA. My qualifications are provided in Appendix J¹ of the MGRA Phase 1 testimony.

Q. On whose behalf are you submitting this testimony?

A. I am submitting this testimony on behalf of the Mussey Grade Road Alliance (MGRA).

Q. What is the purpose of your testimony?

A. The purpose of this Phase 2 testimony is to provide information on wildland fire and power lines that was not available during Phase 1 direct testimony with regard to cost/benefit analysis, to compare the fire risks of the proposed alternatives to SPL, and to discuss material factual inaccuracies and deficiencies in the Draft EIR/EIS.

Q. What new information exists regarding power lines and wildland fires that was not available during Phase 1 testimony?

A. Most notably, there was an extreme Santa Ana wind event during the week of October 21st that caused a number of power line ignitions throughout Southern California, and particularly in the SDG&E service area in San Diego County. This led to massive property loss, loss of life, and exposes SDG&E to potential liability. The impact on San Diego County was significantly worse than that experienced elsewhere in Southern California. This prompted an additional study to determine whether this pattern is true only of the October 2007 fires or

¹ MG-1; Phase 1 Testimony of the Mussey Grade Road Alliance; A.06-08-010; attached as MGRA_Mbar_SPL_AppJ_CV.pdf

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 2 of 69

1 whether it has been historically true. Our testimony then conducts a comparison
2 of fire risks posed by the different alternative transmission routes in a manner that
3 is suggested for the EIR/EIS. Additionally, SDG&E has collected another year of
4 power line ignition data since the submission of the Phase 1 direct testimony
5 analysis was performed, and this data changes and strengthens the conclusions
6 that can be made regarding the potential risk from the proposed SPL project.
7 MGRA will also address material factual inaccuracies and deficiencies in the
8 EIR/EIS, and will include an analysis and critique of the SDG&E wind gust load
9 analysis that should have been included in the Draft EIR/EIS.

10

11 **2. THE OCTOBER 2007 FIRESTORM AND ITS IMPLICATIONS**

12

13 **Q. What occurred during the Santa Ana wind storm that took place the**
14 **week of October 21st, 2007?**

15 **A.** The Santa Ana event that hit Southern California during the week of
16 October 21st was severe. According to Cal Fire², twenty significant fires started
17 during this event. The October firestorm that resulted caused loss of life, massive
18 destruction and dislocation in San Diego County and elsewhere in Southern
19 California, and was reported widely in the press³. The locations of the October
20 2007 fires are shown in Figure 2A-1 of Appendix 2A⁴.

21

22 **Q. What are the implications of these fires for SPL and other power line**
23 **projects?**

24 **A.** Seven of the fires during the October, 2007 fire storm have been attributed
25 to power lines. While investigations are still ongoing for most of these fires, Cal
26 Fire issued a press release in November giving their preliminary conclusion that

² MGRA Phase 2 Direct Testimony, Appendix 2A; data referenced in Section 2A-1.1 “Cal Fire October Fires Data Set”; p. 1.

³ Appendix 2I, attached, contains a list of links to press reports regarding the October 2007 fires.

⁴ Ibid; p. 9.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 3 of 69

1 the Witch, Guejito, and Rice Fires were due to power lines⁵. Additional
2 attributions came from press reports, including those in the Los Angeles Times
3 and in regional papers local to the fires⁶. While not every one of these attributions
4 is guaranteed to correspond to the results of the final investigation by authorities
5 tasked with determining the fire origins, there was a widespread national
6 recognition that power lines constitute an important fire source during Santa Ana
7 wind events⁷.

8 This vindicates the results put forward in the MGRA Phase 1 direct testimony,
9 in which we raised the issue of the risk posed by siting power lines in heavily
10 vegetated areas subject to Santa Ana wind conditions. It also supports our
11 assertion that the economic impacts of power line fires need to be taken into
12 account when addressing the cost/benefit analysis of transmission projects.

13

14 **Q. Do SDG&E and other utilities recognize the importance of the issue of**
15 **power line fires and the need to take action to address it?**

16 **A.** Yes. In fact, in response to the October 2007 fires, SDG&E initiated a
17 Petition to Initiate Rulemaking before the CPUC, requesting that the CPUC “issue
18 a statewide OIR to consider whether to adopt additional or modified regulations
19 and rules with respect to disaster preparedness and management to be
20 implemented by public utilities beyond the current requirements of GO 95.”⁸ This
21 petition received support from Southern California Edison⁹ and Pacific Gas and

⁵ Cal Fire; October Fire Causes; San Diego Unit; Cal Fire News Release; November 16, 2007; described in Appendix 2A, section 2A1-5.

⁶ See Appendix 2A; section 2A-1.8; p. 5 for a list of reports.

⁷ Vick, Karl; Probe of Calif. Fires Lays Most Blame on Power Lines; The Washington Post; Monday, December 24, 2007; Page A03.

⁸ San Diego Gas & Electric Company; PETITION OF SAN DIEGO GAS & ELECTRIC COMPANY (U 902 E) TO ADOPT, AMEND, OR REPEAL A REGULATION PURSUANT TO PUBLIC UTILITIES CODE § 1708.5; November 6, 2007.

⁹ Southern California Edison Company; Response of Southern California Edison Company (U338-E) to Petition of San Diego Gas & Electric Company to Adopt, Amend, or Repeal a Regulation Pursuant to Public Utilities Code §1708.5; CPUC Petition 07-11-007

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 4 of 69

1 Electric¹⁰. Additionally, it received the support of the Center for Biological
2 Diversity and The Sierra Club¹¹, and the Mussey Grade Road Alliance¹², which
3 maintained that an investigation into fire causes should precede any changes to
4 regulations. Additionally, MGRA suggested an outline for addressing fire issues,
5 dividing the problem into sections amenable to a cost-benefit analysis: 1)
6 determining the probability of power line wildland fires 2) determining the costs
7 of power line wildland fires and 3) determining the effectiveness and costs of
8 minimization or mitigation procedures.

9

10 **Q. How do the October 2007 power line fires compare to those started by**
11 **other causes?**

12 **A.** The list of all October 2007 fires is shown in Table 2A-1 of Appendix
13 2A¹³ and is reprinted below for convenience:

14

15

[Remainder of page is left blank]

¹⁰ Pacific Gas and Electric Company's Response in Support of Petition of San Diego Gas and Electric Company; CPUC Petition 07-11-007.

¹¹ Response the Center for Biological Diversity and the Sierra Club to San Diego Gas & Electric Company's Petition to Adopt, Amend, or Repeal a Regulation Pursuant to Public Utilities Code Section 1708.5; CPUC Petition 07-11-007.

¹² Mussey Grade Road Alliance Response To San Diego Gas & Electric Petition To Adopt, Repeal Or Amend A Regulation Pursuant To Public Utilities Code § 1708.5; CPUC Petition 07-11-007.

¹³ Appendix 2A; p. 9.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1

OCTOBER 2007 WILDLAND FIRES

FIRE_NAME	DATE_	SOURCE	COUNTY	ACRE
Non-power line fire Poomacha	11/1/2007	State agency	San Diego	49410.977
Buckweed	10/24/2007	Local agency	Los Angeles	38347.477
Cajon	10/26/2007	USFS	San Bernardino	104.45
Magic	10/26/2007	Local agency	Los Angeles	2728.853
Harris	10/28/2007	State agency	San Diego	90730.055
Santiago	11/1/2007	Local agency	Orange	28173.438
Coranado Hills		San Diego County	San Diego	58.795
Ammo		San Diego County	San Diego	21493.912
Rosa	10/22/2007	Riverside County	Riverside	409.625
Nightsky	10/26/2007	Local Agency	Ventura	53.116
Roca		State Agency	Riverside	0
October	10/23/2007	Local Agency	Los Angeles	0
Total				231,511
Power line fires Canyon	10/24/2007	Local agency	Los Angeles	4329.626
Ranch	10/27/2007	USFS	Los Angeles/ Ventura	58410.354
Rice	10/28/2007	State agency	San Diego	9471.855
Grass Valley	10/29/2007	USFS	San Bernardino	1242.371
Witch	10/31/2007	State agency	San Diego	163240.327
Slide	10/30/2007	USFS	San Bernardino	12769.254
Sedgewick	10/21/2007	USFS	Santa Barbara	808.812
Total				250,273

2

3

4

5

6

7

8

9

10

The above table shows the list of October 2007 fires provided by Cal Fire, divided into those attributed to a power line fire cause and fires due to other causes.

It is noteworthy that seven of the nineteen fires listed are attributed to power line ignitions. As noted in MGRA Phase 1 direct testimony¹⁴, power line fires are historically responsible for only about 3% of ignitions state-wide, though only 1% or less in San Diego County¹⁵, an observation that was confirmed for the numerous San Diego firesheds studied within the scope of the project EIR/EIS¹⁶.

¹⁴ MG-1; Phase 1 Testimony of the Mussey Grade Road Alliance; A.06-08-010; Appendix D., p. 4.

¹⁵ Ibid; p. 9.

¹⁶ California Public Utilities Commission and U.S. Department of Interior Bureau of Land Management; DRAFT Environmental Impact Report/Environmental Impact Statement and Proposed Land Use

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 Using the state-wide average and assuming that power line fires make up 3% of
2 wildland fires, the probability that the observation of seven fires out of 20 as a
3 statistical fluctuation is calculated to be roughly one in 400,000. Much more
4 likely is the mechanism described in the MGRA Phase 1 testimony whereby
5 power line fires are much more likely to occur and grow large during Santa Ana
6 wind events.

7 It can also be seen that fires attributed to power lines were responsible for the
8 majority of the area burned during the October fires (250,000 out of a total of
9 482,000 acres).

10

11 **Q. How did the October 2007 fires affect different counties in Southern**
12 **California?**

13 **A.** The number of fires and the area burned are collected in Table 2A-2 of
14 Appendix 2A¹⁷. This is reprinted below for convenience.

15

16 **POWERLINE (PL) AND NON-POWER LINE FIRES (NPL) BY COUNTY**

County	Non PL	NPL Area	NPL Avg	PL	PL Area	PL Avg
San Diego	4	161,694	40,423	2	172,712	86,356
Los Angeles	3	41,076	13,692	2	33,535	16,767
San Bernardino	1	104	104	2	14,012	7,006
Ventura	1	53	53	1	29,205	29,205
Riverside	2	410	205	0		
Orange	1	28,173	28,173	0		
Santa Barbara	0			1	809	809
TOTAL	12	231,511	19,293	8	250,273	31,284
TOTAL-SD	8	69,817	8,727	6	77,560	12,927

17

Amendment (EIR/EIS); San Diego Gas & Electric Company Application for the Sunrise Powerlink Project; SCH #2006091071; DOI Control No. DES-07-58; Prepared by Aspen Environmental Group January 2008; Section D.15 and also in most Sections E(x).15.

¹⁷ Appendix 2A, p. 10.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 7 of 69

1 As can be seen, San Diego County had the most fires overall (6 – actually 7
2 because the Guejito Fire merged with the Witch Fire and is not independently
3 tallied). Los Angeles County is second with five fires.

4 When it comes to area burned, however, San Diego County overwhelms the
5 statistics, with significantly more area burned by both power line fires and non-
6 power line fires as the rest of Southern California combined.

7 The average area burned by a power line fire was 50-60% larger than that
8 burned by an average fire started by other sources. Interestingly, this is true even
9 if one excludes the data from San Diego (shown by the TOTAL-SD row), whose
10 data overwhelms that of the other counties. One hypothesis that might explain this
11 is that power line fire starts tend to come during periods when the Santa Ana wind
12 conditions are at their most intense, since this is when the damage that causes
13 arcing occurs in the electrical system. Other types of fire starts may come before
14 or after maximum wind conditions, and therefore the wildfires they produce might
15 not spread as quickly and therefore be more amenable to control measures.

16
17 **Q. What were the property damage costs of the October 2007 fires?**

18 **A.** According to the California State Insurance Commissioner¹⁸, the total
19 estimated claims to be filed for property damage as the result of the October 2007
20 fires is \$1.6B. According to the press release issued by Cal Fire in November¹⁹,
21 “The Witch Fire burned 197,990 acres, destroyed 1,650 structures, valued at over
22 \$236 million, costing taxpayers \$18 million in suppression costs. There were two
23 civilian fatalities, 40 firefighters injured. The Rice Fire burned 9,472 acres,
24 destroyed 248 structures, valued at over \$30 million, costing taxpayers \$6.5
25 million in suppression costs.”

26 The bulk of property damage that occurred in the October 2007 fires occurred
27 in San Diego County and was due to the Witch and Rice fires. According to Cal

¹⁸ California Insurance Department; Insurance Commissioner Poizner Hosts Insurance Recovery Forum to Assist San Diego Wildfire Survivors with Recovery Efforts; Press Release; November 29, 2007.
<http://www.insurance.ca.gov/0400-news/0100-press-releases/0060-2007/release120-07.cfm>

¹⁹ Cal Fire; October Fire Causes; San Diego Unit; Cal Fire News Release; November 16, 2007.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 Fire, the Witch Fire was the third largest fire in the history of California (by
2 structures destroyed) while the Rice Fire was the nineteenth largest²⁰.

3 All October 2007 fires that were ranked in the top 20 list of “Structures
4 Destroyed” are listed in the table below:

5

Rank	Name	County	Structures	Deaths
3	Witch	San Diego	1650	2
10	Harris	San Diego	548	6
18	Slide	San Bernardino	272	0
19	Rice	San Diego	248	0

6
7 Of these four, the Witch, Slide and Rice fires have been attributed to power
8 lines.

9 Accordingly, the bulk of lost structures that contributed to the \$1.6B costs of
10 the October 2007 fires referred to by the insurance commissioner must necessarily
11 arise from fires in San Diego County that were ignited by power lines. This
12 implies that if SDG&E were found to be culpable for the start of the Witch and
13 Rice fires, the company could be responsible for damages in excess of \$1B. This
14 is not consistent with the Cal Fire estimates and should be viewed as an upper
15 limit on direct damages that could be recovered. However, additional damages
16 could potentially be recovered under the theory of inverse condemnation or of
17 trespass, as described in Appendix G of the MGRA Phase 1 direct testimony.²¹
18 Potential application of these theories might allow as much as triple damages to
19 be assessed.

20

²⁰ Cal Fire; Fact Sheets; 20 Largest California Wildland Fires; (by Structures Destroyed);
http://www.fire.ca.gov/communications/downloads/fact_sheets/20LSTRUCTURES.pdf

²¹ MG-1; MGRA Phase 1 Direct Testimony; Sunrise Powerlink Transmission Line Project; Application No.
06-08-010; Appendix G.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 9 of 69

1 **Q. Were the MGRA Phase 1 cost estimates reasonably accurate in terms**
2 **of estimating the liability costs accruing from property damage caused by a**
3 **catastrophic power line fire?**

4 **A. Yes.** The MGRA cost estimates used \$1 B as a canonical estimate of
5 property damage that typically accrued during a catastrophic wildland fire
6 encroaching on an urban area.²² This is within the range of damage estimates for
7 the October 2007 San Diego County fires.

8
9 **Q. Are there other monetary damages that could be leveled against**
10 **SDG&E were it to be found culpable for the start of the Witch Fire?**

11 **A. Yes.** The Witch Fire potentially caused significant environmental damage
12 to habitat in San Diego County. This damage would be due to “type conversion”,
13 a term that describes the loss of habitat that occurs when areas burn too often for
14 native vegetation to recover and when invasive grasses and weeds take its place.
15 This process is described by Halsey, who also gives a good listing of the original
16 literature on the topic.²³ It is also described thoroughly in the EIR/EIS.²⁴ The topic
17 of type conversion as a potential source of liability was discussed in Appendix H
18 of the MGRA testimony.²⁵

19 Significant portions of San Diego County were burned in the October 2003
20 fires, and portions of these areas were re-burned in October 2007, making them
21 prone to type conversion and loss of their native Californian vegetation. A large
22 fraction of these lands are under the control of federal, state, and local agencies.
23 Should these agencies decide to take measures to rehabilitate or replace the areas
24 at-risk, they might potentially seek to recover the costs of this mitigation and
25 additional damages from SDG&E if SDG&E is found culpable for the start of the
26 Witch Fire.

²² MG-1; Appendix H; p. 9.

²³ Halsey, Richard W; Fire, Chaparral, and Survival in Southern California; Sunbelt Publications; San Diego; 2005; pp. 25-26.

²⁴ EIR/EIS; Section D2.5; p. D2-82.

²⁵ MG-1, Appendix H, pp. 9-12.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 10 of 69

1 **Q. Did the MGRA accurately estimate the potential costs of damages due**
2 **to type conversion in its Phase 1 analysis?**

3 **A. No.** MGRA significantly underestimated the potential damages that could
4 accrue if SDG&E were held responsible for the power line fire start. For its
5 estimate of area at-risk, MGRA chose a preserve of 2000 acres that had 50% of its
6 area at risk for type conversion. The actual area subject to type conversion as a
7 result of the October 2007 fires is much larger than this.

8
9 **Q. How much area is at risk of type conversion due to the October 2007**
10 **fires?**

11 **A.**MGRA has analyzed the fire perimeters for the October 2003 and October
12 2007 fires in Appendix 2A²⁶, and has found that the total area that was burned in
13 both sets of fires is almost 100,000 acres. According to sources on type
14 conversion²⁷, one would expect that all of this area is at severe risk of
15 permanently losing its native vegetation.

16
17 **Q. What areas could SDG&E potentially be liable for restoring?**

18 **A.**SDG&E could potentially be held liable for restoring public lands that
19 were burned in the October 2003 and then subsequently re-burned in the Witch
20 Fire. These are shown in the two figures below:

21
22
23
24
25
26
27
28


[Remainder of page is left blank]

²⁶ Appendix 2A; pp. 13-17.

²⁷ Halsey.

PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010

1



2

3

4

5

6

7


8

9

The figure shows the area for which the Cedar Fire footprint (dark blue cross-hatch) overlaps the Witch Fire footprint. The vast majority of the holdings are public lands (and Indian reservations), with the U.S. Forest Service being the largest land holder, followed by reservation holdings and also city lands surrounding the El Capitan reservoir.

The area for which the Witch Fire footprint overlaps that for the 2003 Paradise fire is shown in the figure below:

PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010



1
2
3
4
5
6
7
8
9
10
11

This figure is included as Figure 2A-3 of Appendix 2A, and shows the areas burned in the Paradise Fire of 2003 (dark blue cross-hatch), Poomacha Fire of 2007 (maroon cross-hatch, northern area) and the Witch Fire of 2007 (maroon cross-hatch, southern area). The areas overlapped by both the Paradise and Witch Fires are at risk of type conversion.

Land ownership is shown by the colored areas. Once again, one can see that the majority of the area in which the Paradise Fire footprint overlaps the Witch Fire footprint is owned by public agencies, with the U.S. Forest Service being the largest land administrator.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 The areas affected are tallied in Table 2A-3 in Appendix 2A²⁸, printed below
2 for convenience:

3
4 **OWNERSHIP OF LANDS AFFECTED BY THE 2003 AND 2007 FIRES**

	Poomacha-Paradise	Witch-Paradise	Witch-Cedar	Harris-Otay	Total
TOTALS	15148	14370	40647	25801	95966
AGENCY					
U.S. Forest Service	375	7043	22232		29649
Bureau of Land Management	2660		472	7725	10857
Indian Reservations	3447	150	5690		9287
City		1334	2561	2170	6065
California Department of Fish and Game		371		3216	3587
State				2164	2164
County	1667		340	143	2149
U.S. Fish and Wildlife Service				632	632
Water Districts			197		197
School Districts	23				23
TOTAL	8171	8897	31492	16050	64610
Private Lands	6976	5472	9155	9751	31355

5
6 **Q. What would the costs be for rehabilitation or replacement of damaged**
7 **habitat?**

8 **A.** The costs for land rehabilitation as determined by MGRA during Phase 1
9 direct testimony was determined to be between \$5,000 and \$50,000 per acre.²⁹
10 Costs for land replacement would vary from \$4,000 to \$6000 per acre at current
11 prices.³⁰ Applying these to the cost of public lands re-burned in the October 2007
12 fires, we can determine the potential liability costs faced by SDG&E should they
13 be found culpable for the Witch Creek Fire.

²⁸ Appendix 2A; p. 17.

²⁹ MG-1; Phase 1 Testimony of the Mussey Grade Road Alliance; A.06-08-010; Appendix H; p. 16.

³⁰ Ibid; p. 19.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 14 of 69

1 A total of 40,389 acres of the public land at risk is in the Witch Fire area. This
2 means that SDG&E, if responsible for restoration or replacement, could be
3 responsible for direct damages of between \$162 M (for replacement alone) and
4 \$2.1 B (if intensive restoration was done over the entire area). Furthermore,
5 applying triple damages according to the theory of inverse condemnation would
6 increase this range to \$480 M to \$6 B.

7 Hence, potential liability for environmental restoration (if requested by the
8 responsible agencies) could exceed that due to property damage.

9

10 **Q. Are any efforts being undertaken to replace or restore the lands in**
11 **danger of type conversion due to October 2007 fires?**

12 **A.** MGRA currently knows of no agency that is trying to prevent loss of
13 native habitat within its jurisdiction due to type conversion of lands following the
14 successive fire storms in 2003 and 2007.

15

16 **Q. How do these costs affect the Sunrise Powerlink?**

17 **A.** In Appendix H of MGRA Phase 1 direct testimony, we presented an
18 actuarial method by which the costs of fires generated by the SPL would be
19 amortized over the 40 year projected lifetime of the line.³¹ In this method we
20 assumed a 10% chance of catastrophic fire over the lifetime of the line.

21 However the measurements of real data on catastrophic fires should be used
22 instead of the very rough estimates put forward in the Phase 1 testimony. Using
23 this as a baseline, the potential maximum costs amortized over 40 years of
24 operational lifetime of the line would be:

25 \$6 B * 10% / 40 years = \$15 M/yr

26 A lower range, assuming replacement at current land values would be:

27 \$480 M * 10% / 40 years = \$1.2 M/yr

28 However, it would not be trivial to purchase 40,000 acres of mitigation land
29 that could be reasonably said to mitigate for the damage caused. It is likely that

³¹ Ibid; pp. 16-17.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 15 of 69

1 the purchase of such a large quantity of mitigation land would drive up the costs
2 of prime habitat to the point where restoration is the preferred mitigation method.

3 We argue that these costs should be applied to cost / benefit analysis for the
4 proposed transmission line project.

5 Additionally, it was pointed out in the MGRA Phase 1 Opening Brief that
6 catastrophic fires and the increased perception among insurers that power lines
7 are a fire source could significantly raise the cost of insurance that SDG&E will
8 need to pay³². This prospect was also identified in a motion by UCAN, in which it
9 sought to compel additional testimony from SDG&E regarding the October 2007
10 fires.³³ The motion was granted, and so SDG&E will be providing insurance data
11 in their Phase 2 testimony.

12
13 **Q. Why did the SDG&E service area fare so much worse than other**
14 **areas during the October 2007 fires?**

15 **A.** Using existing data, a number of possibilities have been explored as to
16 why the October 2007 power line fires were worse in San Diego County (the vast
17 majority of SDG&E service territory) than elsewhere in Southern California.
18 While no clear cause has been identified by MGRA, a number of hypotheses have
19 been excluded, and a few viable hypotheses remain. Historical fire data up
20 through 2006 were examined to determine whether the October 2007 fires were
21 an anomaly or whether power line fires have been more frequent or severe in San
22 Diego County than in other counties in Southern California.

23
24 **Q. Were the October 2007 fires an anomaly, or have power line fires**
25 **historically been more frequent or severe in the SDG&E service area?**

26 **A.** Power line fires have been more frequent and severe in San Diego County
27 than they have been elsewhere in Southern California. The analysis that led to this

³² OPENING BRIEF OF THE MUSSEY GRADE ROAD ALLIANCE ON PHASE I ISSUES OF THE SUNRISE POWERLINK TRANSMISSION PROJECT; November 9, 2007.

³³ UCAN MOTION TO COMPEL ADDITIONAL SDG&E TESTIMONY RELATING TO WILDFIRES IN PHASE II OF THE PROCEEDING; November 8, 2007.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 conclusion can be found in Section 2B-2.1 of Appendix 2B.³⁴ To determine the
2 number of power line fires throughout Southern California, Cal Fire fire perimeter
3 data (valid through 2006) was analyzed for San Diego, Orange, Riverside, San
4 Bernardino, Los Angeles, and Ventura counties. All fires since 1960 and larger
5 than 100 acres were analyzed, with power line fires being analyzed in parallel.
6 The results of the analysis described in the Appendix and its attached file are
7 given in Table 2B-1³⁵, also shown below:

9 SO. CAL. FIRES LARGER THAN 100 ACRES, 1960-2006

County	Fires	Area (acres)	PL Fires	PL %	PL Area %	PL/All Ratio
Ventura	147	1,160,369	1	0.68	0.34	0.49
Los Angeles	496	1,035,183	3	0.60	0.25	0.41
San Bernardino	272	786,999	2	0.74	0.17	0.23
Orange	53	204,237	1	1.89	1.11	0.59
Riverside	635	1,082,772	1	0.16	2.26	14.33
San Diego	444	1,279,699	6	1.35	19.94	14.76

10

11 The above table shows the county, the total number of fires meeting
12 acceptance criteria, the total area in acres burned between 1960 and 2006, the
13 number of power line fires meeting acceptance criteria during that same period,
14 the percentage of fires that were power line fires, the percentage of total burn area
15 due to power line fires, and the ratio of the last two percentages, which gives the
16 degree to which power line fires are more or less destructive than fires started by
17 other sources.

18 Two remarkable observations can be made. First, San Diego county has the
19 third largest number of large fires (after Riverside and Los Angeles), but has
20 nearly double the number of power line fires (six) of the runner up (Los Angeles,
21 which has three) and has almost the number of power line fires observed in the
22 rest of Southern California put together (six for SD versus eight for the rest).

³⁴ Appendix 2B; p. 7.

³⁵ Appendix 2B; p. 9.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 17 of 69

1 Secondly, the observation made during Phase 1 testimony that power line fires
2 are much larger than fires started by other sources³⁶ seems to be borne out only
3 for San Diego and Riverside counties, and is not observed in the data from other
4 counties. In fact, data from other counties indicates that power line fires have
5 been *smaller* than average fire starts from other types of fires. This result needs to
6 be taken with some caution, since the statistical nature of fire data implies that
7 over large averages, the statistics will be driven by the largest and most
8 catastrophic events.³⁷ Because our data sample is so small, data from other
9 counties did not (up to 2006) contain catastrophic events, while the much larger
10 sample of all fires does. This makes the ratio of the two numbers smaller.

11

12 **Q. How statistically significant is the observation that San Diego has**
13 **many more power line fires than other counties in Southern California?**

14 **A.** Assuming that there is an equal probability of fires being started in any
15 particular county, we can calculate what this average is, and then calculate the
16 probability that the high number of power line fires in San Diego County is a
17 statistical fluctuation.

18 There were eight power line fires, total, in the five counties other than San
19 Diego, for an average of 1.6 fires per county. The statistical probability that the
20 observed number of fires is consistent with the hypothesis of an equal number of
21 fires per county is 0.9%.

22

23 **Q. How does the Draft EIR/EIS address the comparative fire risk of**
24 **power lines in San Diego versus other counties in Southern California?**

25 **A.** The Draft EIR/EIS does not address the issues of comparative fire risk due
26 to geographical location. This is a material factual deficiency of the EIR/EIS.

27

³⁶ MG-1; MGRA Phase 1 Direct Testimony, Appendix D- Power Line Fires; pp. 9-10; Sunrise Powerlink Transmission Line Project Application No. 06-08-010

³⁷ Moritz, Max A., et. al; Wildfires, complexity, and highly optimized tolerance; Proceedings of the National Academy of Sciences of the United States of America; December 13, 2005; vol. 102; 17913.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 18 of 69

1 **Q. Is the assumption that there is an equal probability of a power line**
2 **fire start in any given county reasonable?**

3 **A. No.** The areas, vegetation, terrain and populations of the counties in
4 southwest California are not equal and the assumption that there is an equal
5 probability of a fire start in any given county is not reasonable.
6

7 **Q. Could the number and destructiveness of power line fires in San**
8 **Diego County compared to other counties be due to differences in the amount**
9 **fire-prone vegetation?**

10 **A. An analysis, performed in section 2B-2.2³⁸, shows only a partial reduction**
11 in the significance of San Diego’s excess of power line fires if they are assumed
12 to be proportional to the amount of hazardous vegetation. San Diego remains
13 higher than any other county, but the statistical significance is reduced.

14 This analysis was performed by tracing the general areas which had a Cal Fire
15 Threat level of “High”, “Very High”, or “Extreme” for each county and assuming
16 that the probability of a fire start was proportional to these areas.

17 These fire threat contours are shown in Figure 2B-1 of Appendix 2B, also
18 shown below:

[Remainder of page is left blank]

20

³⁸ Appendix 2B, pp. 11-14.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**



1
2
3
4
5
6
7

The areas outlined in red in the figure were assumed to be proportional to the hazard and used to calculate the expected number of fire starts. These are compared to observed power line start rates in the table below:

CALCULATED POWER LINE FIRE THREAT (VEGETATION) BY
COUNTY

Counties	PL Fires	Threat (acres)	PLF/ acre	Pred. (A-SD)	Prob.
Ventura	1	916,355	1.1E-06	1.7	
Los Angeles	3	1,179,430	2.5E-06	2.2	
San Bernardino	2	752,014	2.7E-06	1.4	
Orange	1	167,669	6.0E-06	0.3	
Riverside	1	1,286,175	7.8E-07	2.4	
San Diego	6	1,630,266	3.7E-06	3.0	19.8%

8
9
10
11
12

As can be seen, San Diego does in fact have a larger area of hazardous vegetation (“Threat area”) than any other county in Southern California. If we calculate the number of historical power line fires per acre of threat area, we see that San Diego is still high, but not as high as Orange County.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 20 of 69

1 . Calculation of the statistical significance shows that the excess of power line
2 fires in San Diego County may be partially explained by the large amount of
3 flammable vegetation in the County.
4

5 **Q. Is the hypothesis that the number of power line fires will be**
6 **proportional to the area of flammable vegetation a reasonable one?**

7 **A.** Not really. It forces that the unreasonable assumption that the electrical
8 infrastructure is uniformly distributed throughout the hazard zone. In fact, much
9 of this hazard zone is hazardous because it is rural, remote, and undeveloped.
10 Hence it is unlikely to have much transmission or distribution infrastructure in
11 place in comparison to more highly urbanized areas of lower threat.
12

13 **Q. Are we able to measure the exposure of hazardous vegetation to**
14 **power lines?**

15 **A.** No, not directly. SDG&E considers providing its line location information
16 a security issue, and has refused to give it to MGRA.³⁹ Additionally, this would
17 be a difficult task to perform for distribution lines, which make up the bulk of the
18 data.

19 A possibly equivalent hypothesis is that there will be more power lines where
20 there are more people. This will certainly be true for distribution lines, which are
21 shorter and near homes and businesses. Since there is a much more extensive
22 distribution network than there is a transmission network, a correlation between
23 power lines and population probably exists. This can be combined with the
24 vegetation threat regions defined above to estimate risks to individuals and
25 households due to power line fires.
26
27
28

³⁹ SDG&E'S 2/6/07 RESPONSE TO MGRA Data Request No. 2.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 **Q. Taking into account population density and vegetation, what is the**
2 **significance of San Diego’s excess of power line fires?**

3 **A.** The analysis performed in section 2B-2.3 of Appendix 2B⁴⁰ shows that
4 taking population into account does not reduce the significance of San Diego’s
5 excess of power line fires. It makes them far more significant than taking into
6 account vegetation alone.

7 This analysis was performed by using census tract data provided by ESRI,
8 valid as of 2007.⁴¹ US census tracts were selected for Southern California, and
9 only those falling within 300 meters of the “Fire Threat” zones shown within the
10 previous figure were kept. This is shown in Figure 2B-2 of Appendix 2B. The
11 number of housing units (as of 2000) was used as a proxy for the electrical
12 network size, and this was summed per county. The result is shown in Table 2B-
13 3 of Appendix 2B, and also shown below:

CALCULATED POWER LINE FIRE THREAT (POPULATION) BY
COUNTY

County	PL Fires	Housing Units Tht.	PLF/ HUT	Pred. (A-SD)	Prob.
Ventura	1	101,654	9.84E-06	1.15	
Los Angeles	3	406,282	7.38E-06	4.61	
San Bernardino	2	211,755	9.44E-06	2.40	
Orange	1	109,326	9.15E-06	1.24	
Riverside	1	234,633	4.26E-06	2.66	
San Diego	6	170,028	3.53E-05	1.93	0.16%

17
18 The number of housing units in the threatened areas are listed in the third
19 column. As is evident, while San Diego County might have the largest area
20 enclosed in the “High” fire threat contours, the number of housing units enclosed
21 is modest compared with some of the more densely populated areas of Southern
22 California. Los Angeles, Riverside, and San Bernardino counties all have a larger

⁴⁰ Appendix 2B; pp. 14-17.

⁴¹ ESRI; Tele Atlas North America, Inc.; 20070501; Redlands, California, USA; ESRI® Data & Maps; 2007 World, Europe, United States, Canada, and Mexico; *available with ArcGIS9.2 distribution.*

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 22 of 69

1 number of housing units within the tracts bordering or contained in the high fire
2 risk contours. Remarkable uniformity is now seen in the fire rates between all
3 counties in the power line fire rates – aside from San Diego County, which has a
4 value 3.5 times larger than the average (and Riverside County, which with its one
5 event is a factor of two low).

6 The probability that the large number of San Diego fires is due to a statistical
7 fluctuation is estimated at 0.16%. These results imply that a home in the San
8 Diego wildland urban interface is more than 3.5 times as likely to be exposed to a
9 power line fire in San Diego County than it would be in other southwest
10 California counties.

11

12 **Q. Is the hypothesis that the exposure of powerlines to hazardous**
13 **vegetation will be proportional to the number of housing units in the hazard**
14 **area valid?**

15 **A.** Possibly. It is likely that there will be a strong correlation between power
16 line extent and number of housing units, though probably not a direct
17 proportionality. More “rural” areas will tend to have longer runs of distribution
18 line per structure, on the average, than more urbanized areas. Additionally, there
19 has been a significant increase in building in rural areas since the 2000 census,
20 though this would be expected to affect all Southern California counties and not
21 just San Diego.

22 Also, power line fires require the correlation of power lines, flammable
23 vegetation, and wind. This result does not take into account any localized wind
24 effects.

25

26

27

28

29

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 23 of 69

1 **Q. Could wind conditions be more severe in San Diego County than**
2 **elsewhere in Southern California?**

3 **A. This is unlikely, though the data from the October 2007 Santa Ana event**
4 **are ambiguous. An analysis performed in Section 2B-2.4 of Appendix B⁴²**
5 **compares the Santa Ana wind conditions in San Diego County in two different**
6 **ways. It examines the data from six Santa Ana events both in terms of predictions**
7 **from the National Weather Service and alternatively uses data from weather**
8 **stations.**

9

10 **Q. What is the correct way to analyze Santa Ana wind conditions?**

11 **A. There is no mechanism as yet that allows accurate and fine-grained**
12 **characterization of Santa Ana weather events. Computer models are in**
13 **preparation that may allow this, but they are not available as of yet⁴³.**
14 **Nevertheless, analysis of wind conditions along the proposed and alternative SPL**
15 **routes using currently available weather data and analysis should and can be**
16 **performed. The MGRA Phase 1 Opening Brief requested that wind data be**
17 **analyzed as part of the Draft EIR/EIS⁴⁴ in order to allow comparison of power**
18 **line fire hazard along proposed and alternative routes. No analysis of this type**
19 **was performed, which constitutes a material factual deficiency in the EIR/EIS.**

20 Data from the National Climate Data Center's National Forecast Database can
21 be used to construct typical examples of Santa Ana events. These tend to be
22 coarse grained and do not take into account local topology, and are only
23 predictions rather than actual measurements. Weather station data, on the other
24 hand, while very accurate only represents one local area and it may not always be
25 representative of the region surrounding it. Furthermore, publicly available
26 digital data only exists for several years (nine years for RAWS weather station
27 data, two years for NDFD predictions). Under these limitations, MGRA

⁴² Appendix 2B; pp. 17-25.

⁴³ Moritz, Max; private communication.

⁴⁴ MGRA Phase 1 Opening Brief; pp. 7-8.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 25 of 69

1 Whittaker Peak in Los Angeles County, a mountain station, and MBU, Malibu
2 Hills, quite close to the town of Malibu. It should be noted that a likely reason that
3 the MBU station did not rank highly during the October 2007 event was that its
4 data was incomplete so it was not included. Its location was very close to the
5 Canyon Fire footprint, and it was likely damaged, disabled, or relocated as a result
6 of the fire.

7 It should also be noted that according to the weather stations, the event that
8 started 1/6/2007 was even more severe than the one that started 10/21/2007, as
9 measured in all three ranks.

10 Taken as a whole, there is nothing in this data that would suggest that Santa
11 Ana events are more severe in San Diego County than anywhere else. In fact, one
12 could easily reach the opposite conclusion.

13

14 **Q. How do National Climate Data Center wind gust predictions compare**
15 **between counties in Southern California?**

16 **A.** The results of the computer modeling vary greatly from event to event,
17 and also vary with time as the high pressure system causing the event passes
18 through the area. The most severely affected county is not necessarily the same
19 for each event. NDFD data was collected for three hour intervals for five Santa
20 Ana events between 2006 and 2007. Since there is currently no accepted way of
21 turning these into hazard maps, we can compare examples against the results from
22 weather station data. Data on the 1/6/2007 event, plotted in Figure 2B-5, also
23 displayed below, confirms that the most active region during this event was in the
24 northern regions of Southern California:


25

26

[Remainder of page is left blank]


27

PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010



1
2
3
4
5
6

However, the most intense wind prediction seen for any event was calculated to be in San Diego County during the October 21, 2007 event. This maximum wind event is displayed in Figure 2B-4, and is also shown below:



7
8

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 27 of 69

1 It is important to note that the prediction in the above figure is for two hours
2 prior to the start of the Witch Fire, which occurred west of the Julian weather
3 station (JLN) in the area of maximum predicted wind speeds.
4

5 **Q. Could inadequate fire protection lead to the observed excess and**
6 **destructiveness of power line fires in San Diego County?**

7 **A.** According to the analysis performed in Appendix 2B, section 2B-2.5,
8 there is no evidence that fires since 1990 in San Diego County have been any
9 more frequent or larger (with the exception of the Cedar Fire) than fires in other
10 counties in southwest California. A recent report⁴⁷ has chided San Diego County
11 for lack of fire protection funding, and press accounts⁴⁸ following up on this
12 report have pointed out that San Diego County spends only \$8M on fire
13 protection, whereas Los Angeles County spends \$860M and Orange County
14 spends \$260M. These numbers on their own are deceptive, because very little of
15 San Diego County's fire protection activities are carried out by the County of San
16 Diego. Instead, San Diego County is Balkanized into numerous city and rural fire
17 protection agencies that are independently funded. A study of the unincorporated
18 areas that is laying the ground for the creation of a county-wide fire service
19 calculates that the funding of the unincorporated areas alone in 2003 totaled
20 \$47M.⁴⁹

21 Regardless of funding or structural characteristics of San Diego's fire
22 protection infrastructure, if it were to be deeply problematic this would be
23 indicated by a greater frequency of large fires and a larger fire size in San Diego
24 County than elsewhere. Using the Cal Fire historical fire data again, Appendix 2B

⁴⁷ San Diego Regional Fire Safety Forum; <http://www.sdfiresafety.org/>

⁴⁸ Welch, William M.; Report: San Diego failing at fire safety; USA Today; February 19, 2008;
http://www.usatoday.com/weather/wildfires/2008-02-19-sandiego-fire_N.htm?csp=34

⁴⁹ San Diego Local Agency Formation Commission (LAFCO); MACRO REPORT; Options for Providing
Structural Fire Protection and Emergency Medical Services in Unincorporated San Diego County;
December 5, 2005; p. 9. http://www.sdlafco.org/document/MACRO%20REPORT_wo_maps.pdf

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 looks at the total number of fires after 1990 in each of the counties studied.

2 Results are summarized in Table 2B-7, also reprinted below:

3
4 ALL FIRES >100 ACRES, BY COUNTY

County	Fires >1990	Area (acres)	Average	Median
Ventura	57	604,260	10601	820
Los Angeles	156	298,048	1911	321
San Bernardino	94	441,943	4702	555
Orange	20	62,589	3129	696
Riverside	188	384,812	2047	421
San Diego	131	692,482	5286	501

5
6 As can be seen, the number of fires greater than 100 acres in San Diego is no
7 larger than that observed in other Southern California Counties. Its average fire
8 size is somewhat large, at 5,286 acres, but most of this can be accounted for by
9 the Cedar Fire, which added 270,000 acres to the total area burned in San Diego
10 County. Minus this event, total area burned would be typical of other comparable
11 counties. Likewise, the median fire size in San Diego (a better representation of a
12 “typical” fire than the average due to the size distribution statistics for wildland
13 fires) is within the typical range of the other counties.

14 We can conclude that whatever funding or organizational irregularities may
15 exist in San Diego County, these do not lead to a measurable reduction in the
16 quality of fire protection in comparison to other Southern California counties.

17
18 **Q. What are the implications the large number of power line fires in San**
19 **Diego County for Sunrise Powerlink?**

20 **A.** The analysis described above was to attempt to identify possible causal
21 mechanisms that could explain the excess fires, so that we can then determine
22 whether these mechanisms would have implications for Sunrise Powerlink.
23 Correlations with areas of flammable vegetation were observed, but not enough to
24 explain the entire effect. A considerable portion of MGRA Phase 1 testimony was

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 29 of 69

1 devoted to the high exposure of the proposed SPL route to flammable
2 vegetation⁵⁰, as is a considerable portion of the Draft EIR/EIS treatment of fire
3 issues.⁵¹ The observed correlation, if correct, would add further weight to the
4 argument that we are increasing the risk of significant power line fires by routing
5 the SPL through areas of hazardous vegetation.

6 However, attributing the enhanced fire rate to the exposure of power lines to
7 hazardous vegetation areas due to encroachment of people and structures into
8 these areas seems to be ruled out by census data. Other counties have more of this
9 encroachment than San Diego.

10 Attributing the excess to wind meets with ambiguous results. According to
11 weather station data, weather stations in San Diego County do not experience
12 Santa Ana weather conditions that are worse than those recorded elsewhere. This
13 leaves the question of the excess fires unresolved.

14 The National Digital Forecast Database (NDFD) predictions, however, show
15 an anomalously strong event over San Diego County during the week of October
16 21, 2007. It might be hypothesized that the “worst of the worst” Santa Ana events
17 occur in San Diego County. If this were to be true, it would mean that the SPL
18 (and alternative routes that go through the wind hazard area, as most of them do),
19 might be exposed to abnormally high winds. According to SDG&E’s Phase 1
20 Reply Brief, the expected wind conditions for SPL were calculated based upon
21 the results of nearby weather stations.⁵² If the NDFD data for the October 2007
22 Santa Ana event is more accurate than that from the weather stations nearby
23 (which could be true if the weather stations were not properly positioned to
24 experience the full strength of Santa Ana events), this would imply that the SPL
25 engineering calculations might not be rigorous enough in the maximum wind
26 area. If, on the other hand, the NDFD predictions were incorrect and the weather

⁵⁰ MG-1; MGRA Phase 1 Direct Testimony; pp. 20-26.

⁵¹ Draft EIR/EIS; Section D.15 and also in most Sections E(x).15.

⁵² San Diego Gas and Electric Company; PHASE 1 REPLY BRIEF OF SAN DIEGO GAS & ELECTRIC COMPANY; November 30, 2007; p. 155-156.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 station data more representative, then there is still no explanation for the excess of
2 power line fires in San Diego County or their destructiveness.

3

4 **Q. What other possibilities might explain the excess of power line fires**
5 **and their destructiveness?**

6 **A.** One other possibility is that maintenance of lines and equipment by
7 SDG&E is worse than that practiced in other utility service areas, leading to
8 greater fault rates and fire starts. With this possibility in mind, MGRA requested
9 maintenance records for SDG&E's 230 kV and 500 kV network.⁵³ These were
10 provided as confidential information to MGRA. These are of limited value,
11 however, because in order to determine how SDG&E's practices compare to that
12 of other utilities would require that the maintenance records be compared with
13 other companies, which is not possible under the scope of this proceeding. MGRA
14 has, nevertheless, reviewed the data and as of yet has discovered no patterns
15 suggestive of a maintenance problem. If insufficient maintenance were to be at
16 the root of the excess of power line fires in San Diego County, the implications
17 for the SPL would be that safeguards would need to be put in place to ensure
18 proper maintenance of the proposed project takes place, and these would need to
19 be specified in the EIR/EIS. Additionally, the added costs for implementing these
20 safeguards would need to be added to the cost of the project.

21 In fact, regardless of the source of the excess of power line fires in San Diego
22 County, it is clear that SDG&E could be taking more aggressive measures to
23 address this risk. Even if there is full compliance with GO 95 and other best
24 practices, if the conditions in San Diego are somehow more hazardous than those
25 found elsewhere in Southern California, it would be incumbent upon SDG&E to
26 mitigate for these conditions if it wishes to do business in this area. Such
27 mitigation measures should be included in the cost of the SPL project and
28 included in the scope of the Phase 2 testimony.

29

⁵³ MGRA Data request #5 to SDG&E.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 31 of 69

1 **Q. Does the analysis above give an exhaustive list of possible causes for**
2 **the excess of power line fires observed historically in San Diego County?**

3 **A. No.** There could be other possible causes as yet not suggested by MGRA.
4 The purpose of the analyses in Appendix 2B was to address a number of
5 reasonable hypotheses. None of those addressed give an unambiguous explanation
6 of the excess.

7

8 **3. COMPARISON OF THE PROPOSED AND ALTERNATIVE ROUTES**

9

10 **Q. Does the Draft EIR/EIS⁵⁴ for the Sunrise Powerlink project analyze**
11 **fire risk as a means of comparing alternatives to the project?**

12 **A. Yes.** The Draft EIR/EIS devotes over 300 pages of analysis to fire issues
13 related to the Sunrise Powerlink project. It applies three general analysis methods
14 that are used for route comparison:

15 1) A general survey of vegetation and other fire-relevant conditions was done
16 along the main route and a hazard metric was developed and applied to each
17 route.

18 2) Fire modeling was done in which ignition points were placed along the route
19 and the fire allowed to propagate under mild and extreme Santa Ana conditions.
20 Burn areas and structures at risk were determined in this fashion.

21 3) Factors affecting the difficulty of firefighting along the route were done on a
22 per-segment basis, taking into account overhead lines, remoteness, ruggedness of
23 terrain and other factors relevant to wildland firefighting.

24 Based upon these analyses, a comparison of routes was done in Section H of
25 the Draft EIR/EIS, and the routes were ranked in order of preference due to fire
26 hazard.

⁵⁴ California Public Utilities Commission and U.S. Department of Interior Bureau of Land Management; DRAFT Environmental Impact Report/Environmental Impact Statement and Proposed Land Use Amendment (Draft EIR/EIS); San Diego Gas & Electric Company Application for the Sunrise Powerlink Project; SCH #2006091071; DOI Control No. DES-07-58; Prepared by Aspen Environmental Group January 2008.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 32 of 69

1 **Q. Is the Draft EIR/EIS route analysis based upon fire hazard complete**
2 **and correct?**

3 **A.** The fire analysis done in the Draft EIR/EIS is a superbly detailed and very
4 thorough treatment of fire issues affecting the routes. In its Phase 1 brief⁵⁵
5 requested that as part of the CEQA review: “All alternative routes need to be fully
6 analyzed with respect to wildland exposure and fire hazards in a way that
7 compares hazard combinations on a mile-by-mile basis.” The route analyses
8 performed in the Draft EIR/EIS⁵⁶ form a foundation for performing such an
9 analysis.

10 However, the Draft EIR/EIS has a number of substantive shortcomings and
11 material factual deficiencies that need to be corrected. Many of these will be
12 addressed more fully in a subsequent section. Presently, we note that the analysis
13 in Section H of the Draft EIR/EIS lacks a fully quantitative comparison between
14 routes. The methodology used for the burn probability model and the wildfire
15 containment conflict model would lend itself very well to a quantitative summary
16 of route segments, but such a quantitative comparison has not been done.

17

18 **Q. Has the MGRA performed a quantitative comparison of the routes**
19 **based upon fire hazard?**


20 **A.** Yes, following the methodologies laid out in Appendix D of the MGRA
21 Phase 1 Direct Testimony, a comparative analysis has been done between routes
22 based upon Cal Fire fire metrics and vegetation type maps. This is presented in
23 Appendix 2C. As in the Phase 1 analysis, the routes are broken into one kilometer
24 segments, and the conditions along each segment are collected for a number of
25 different types of GIS data. These are gathered into the Excel spreadsheet file
26 RouteAnalysis_SPLAlt.xls, which is submitted with this testimony. The routes

⁵⁵ MGRA; Phase 1 Opening Brief; p. 44.

⁵⁶ Draft EIR/EIS; Section D.15.4.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 studied by this analysis, superimposed on a Cal Fire Threat⁵⁷ map, are shown in
2 Figure 2C-1, which is also displayed below:



3
4 This figure shows the proposed SPL route along with the “Environmentally
5 Superior” Northern and Southern routes, as well as LEAPS and the Southwest
6 Powerlink (SWPL – for reference only). The additional 69 kV segment along the
7 Talega-Escondido route, which would be required in conjunction with LEAPS, is
8 also shown. Differently colored areas represent different levels of fire threat as
9 calculated by Cal Fire.

10

11 **Q. What conclusions can be reached regarding the SPL route and all**
12 **alternative routes?**

13 **A.** As the map above makes clear, all the alternative transmission routes have
14 significant exposure to hazardous vegetation and conditions that create a
15 significant fire threat. This coincides with the results of the Draft EIR/EIS, which

⁵⁷ Appendix 2C; 2C-1.3; p. 3.


**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 concludes that all transmission routes have a Class I impact⁵⁸, listed as impact F-
2 2: “Presence of the overhead transmission line would increase the probability of a
3 wildfire.”⁵⁹ These impacts affect all non-desert firesheds of the proposed and
4 alternative routes, including many communities such as Poway, Ramona, Santa
5 Ysabel, Campo and Potrero.

6

7 **Q. What advantages are there to the approach taken in this testimony**
8 **over that taken in the Draft EIR/EIS?**

9 **A.** While all routes have Class I impacts, some routes have significantly more
10 exposure to hazardous conditions than other routes. This can be quantified. The
11 approach taken by in the analysis performed in Appendix 2C and the attached
12 spreadsheet makes this straightforward. We show a comparison of vegetation
13 along the proposed and alternative routes classified as to potential flame lengths
14 according to Scott-Burgan vegetation classifications⁶⁰ in Figure 2C-4, reprinted
15 below:



16

⁵⁸ Draft EIR/EIS; Appendix H, multiple locations.

⁵⁹ Draft EIR/EIS; pp. D.15-70 – D.15-71 and multiple locations.

⁶⁰ Appendix 2C, Section 2C-1.2; p.2.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 This figure shows the exposure of the line segments to vegetation of various
2 hazard classes, with 1 representing flame lengths of 5 feet or less in a 10 mph
3 wind, class 2 representing flame lengths from 5 to 15 feet, and class 3
4 representing flame lengths over 15 feet. Five routes are analyzed, indicated by
5 the bar graphs of different color. In this manner, the hazard present along each
6 route can be quantitatively compared. The results from the analysis performed in
7 Appendix 2C are summarized in the table 2C-1, reprinted below:

8
9 **COMPARISON OF FIRE METRICS FOR ALL ROUTES**

Route	CF Fuel > 1	CF Threat >1	SB Vegetation >1
SPL	106	104	127
ESSA	129	131	121
SWPL	95	95	83
ESNA	48	49	65
LEAPS	56	54	62

10
11 A table of this type allows direct comparison of routes to be quantified. From
12 this table we can glean that the greatest fire threat would be created by the
13 proposed SPL route and by the Environmentally Superior Southern Alternative.
14 A lesser exposure to flammable vegetation and conditions would occur if either
15 the Environmentally Superior Northern Alternative or LEAPS were to be
16 constructed.

17 This type of analysis is lacking in the Draft Environmental Impact Report /
18 Environmental Impact Statement (Draft EIR/EIS), and both the burn probability
19 model and the wildfire containment conflict model could be adapted to this
20 approach in a straightforward manner. This is a significant shortcoming in the
21 current version that should be addressed in the final Draft EIR/EIS.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 36 of 69

1 **Q. Are there flaws in the data used in either the Draft EIR/EIS or in the**
2 **data used in the analysis in Appendix 2C?**

3 **A. Yes, there is a significant shortcoming in both data sets. The data used for**
4 both the Cal Fire fuel load and fire threat metrics was based upon a 2004 survey
5 that occurred in the aftermath of the Cedar fire. This fire temporarily reduced the
6 fuel hazard ranking over a wide area, much of which is traversed by the proposed
7 route for SPL. Fuel load can be expected to return to much higher levels than
8 those measured during the lifetime of the project. This was confirmed by
9 SDG&E's witness Hal Mortier during cross-examination.⁶¹ This bias is also
10 present for the Scott-Burgan vegetation analysis, but the effect is less evident.

11 All analyses performed within the EIR/EIS – the burn probability model, fire
12 behavior modeling, and the wildfire containment conflict model are subject to the
13 same bias encountered in the MGRA analysis. Analyses were based upon field
14 studies conducted in 2006 or 2007, when the fuel load in the Cedar Fire footprint
15 has still not approached the value expected to be typical over the lifetime of the
16 proposed project. This will cause these models to significantly under-predict the
17 future fire risk within the Cedar Fire perimeter. This preferentially would affect
18 the proposed SPL route and the Environmentally Superior Northern Alternative,
19 since these routes have the longest traversal through the Cedar Fire footprint, with
20 the net result that these routes would be shown to have a lower comparative fire
21 risk than would be expected to be present during most of the lifetime of the
22 proposed project.

23 This effect is not mentioned in the Draft EIR/EIS. No mention is made of
24 measures that might have been taken to compensate for this bias, or the effect of
25 the bias. This is a significant shortcoming, and needs to be addressed in the final

⁶¹ Cross Examination of witness Mortier; Public Utilities Commission, State of California; A0608010; July 17, 2007; p.1007.

Exhibit MG – 10; CDF Fire Threat - Pre-Cedar (2003)/Pines(2002) Fires;

Exhibit MG – 11; CDF Fire Threat - Post Cedar (2003)/Pines (2002) Fires;

Exhibit MG – 12; CDF Fire 2003 - Pre-Cedar/Pines Enlarged "Sunrise" Northern Loop

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 37 of 69

1 EIR/EIS. Preferably, a method should be found to correct for the bias. If this is
2 not possible to do in a correct and rigorous way, the bias introduced by the Cedar
3 Fire footprint needs to be fully disclosed and its effect on the conclusions of the
4 EIR/EIS discussed.

5

6 **4. SDG&E OUTAGE AND FIRE DATA FOR 2007**

7

8 **Q. What new information is available regarding fires and powerlines**
9 **that was not available during the Phase 1 testimony?**

10 **A.** Fire rates for transmission lines in the SDG&E network based on SDG&E
11 fire history data were calculated as part of the MGRA Phase 1 testimony.⁶² This
12 showed that power line fires – even those from 230 kV lines – did not have a
13 negligible rate of occurrence and could well be an issue for the SPL project. This
14 assertion was challenged by SDG&E in its rebuttal testimony.⁶³ The Draft
15 EIR/EIS also gives the impression that fires from larger transmission lines are
16 unlikely: “There is a public perception that all power lines can be a direct cause of
17 wildfire ignitions, but power line-caused fires are much more prevalent for
18 distribution and lower-voltage transmission lines compared with higher-voltage
19 transmission lines such as the Proposed Project.”⁶⁴ This must be considered a
20 shortcoming in the Draft EIR/EIS.

21 Two things have happened since the Phase 1 testimony was submitted that
22 confirm and solidify our original conclusions:

- 23 • The October 2007 fire storms demonstrated clearly the link between
24 power lines, vegetation, and Santa Ana winds that was put forward in the
25 MGRA testimony.

⁶² MG-1; MGRA Phase 1 Direct Testimony, Appendix B – SDG&E Power Line Fires; pp. 5-9; Sunrise Powerlink Transmission Line Project Application No. 06-08-010.

⁶³ SD-32; PREPARED REBUTTAL TESTIMONY OF HAL MORTIER ON BEHALF OF SAN DIEGO GAS & ELECTRIC COMPANY; July 15, 2007; Sunrise Powerlink Transmission Line Project Application No. 06-08-010; pp. 6-7.

⁶⁴ Draft EIR/EIS; Section D-15 – Fire and Fuels Management; pp. D.15-2 – D.15-4.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 38 of 69

- 1 • Yet another significant fire occurred due to a 230 kV line in the SDG&E
2 service area, when according to SDG&E records, a 230 kV started a fire
3 under windy conditions on Stuart Mesa in June of 2007. This is very
4 important, in that it means that the Camp Pendleton event in 2006 is not a
5 singular event. This allows us to make more accurate predictions of the
6 actual fire rates expected for 230 kV lines.

7

8 **Q. What is the relevance of this testimony for Phase 2?**

9 **A.** These new data allow recalculation of predicted fire rates for SPL, and
10 hence allow reformulation of project cost that incorporates wildland fire liability,
11 as described in Appendix H of the MGRA Phase 1 testimony. Furthermore, as
12 will be shown, 2007 fire data belies the assertion that lower voltage transmission
13 lines have a higher fire ignition rate than higher voltage lines “such as the
14 Proposed Project”, thus revealing an erroneous assertion in the Draft EIR/EIS.
15 Finally, the MGRA analysis put forward in Appendix 2D calculates predicted fire
16 rates for proposed transmission alternatives to the SPL project. We also carry out
17 fire rate analysis assuming several planned expansions of the project that are
18 mentioned in the EIR/EIS but not analyzed by the EIR/EIS (constituting a
19 material factual deficiency in the Draft EIR/EIS).

20

21 **Q. How are the power line fire rates determined?**

22 **A.** Predicted rates for power lines are derived using a method identical to that
23 which we applied in Appendix B of the Phase 1 MGRA Direct Testimony.⁶⁵ We
24 take the SDG&E fire history from March 2004 to November 2007 and have
25 separated out events caused by human or animal activity (vehicle collisions,
26 construction, gun shots, plane crashes, kites, balloons, birds) from those due to
27 mechanical failure, wind damage, trees, or other that might be relevant during a
28 Santa Ana event.

⁶⁵ MG-1; MGRA Phase 1 Direct Testimony; Appendix B; pp. 5-9.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 SDG&E has specified which fires were caused by transmission lines and which
2 were caused by distribution lines. Unfortunately they did not specify the voltage
3 of the transmission lines. This was easily remedied in this analysis by cross-
4 referencing the fire record to the outage history supplied by SDG&E⁶⁶.

5 The categories of were further broken down into distribution, 69/138 kV, and
6 230 kV initiated fires. Once again, there were no 500 kV fires in 2007. This is
7 shown in the fire history file as modified by the MGRA⁶⁷ to highlight these
8 separate categories. These are summarized in Table 2D-1 in Appendix D, also
9 shown below:

Dist - Failure/Wind/Tree	75
Dist - Human/Bird	33
69/138 kV - Human/Bird	6
69/138 kV - Failure/Wind	4
230 kV - Failure/Wind	2

11
12 It is evident that there were two 230 kV power line failures that caused fires in
13 the 2004-2007 time frame. At the time that the MGRA Phase 1 testimony was
14 written, there was only one, opening up the possibility that this one event was
15 some sort of anomaly. This is now much less likely. We can say definitively that
16 “the big lines cause fires”. This is of course relevant to SPL because significant
17 portions of the proposed SPL and some alternatives will consist of 230 kV lines.

18 All transmission line fires listed in the SDG&E data between 2004 and 2007
19 are listed in Table 2D-2, also listed below. New data not presented during Phase 1
20 is indicated by violet highlighting.

⁶⁶ Appendix 2D; File 2D-1; SDGE_Outages_2007.xls; attached.

⁶⁷ Appendix 2D; File 2D-2; MGRA DR5-41 SDGE Fire Cause Data 2004; attached.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1

Date	Incident	Location	Voltage⁶⁸ (kV)	Acres	Cause
3/15/2005	Otay Substation	Metro	69	0.1	Mylar balloon into 69 kV, 10 x 60 spot
7/3/2005	Miller Valley	Mountain Empire	69	19	Mid-line slap, static line (Contractor)
7/12/2005	Eastlake	Metro	69	0.1	Dust, dirt on insulator/relay, sm. Spot
7/28/2005	San Clemente	Orange County	69	1	Corrosion/wire down, 1 acre brush fire
8/5/2005	Corte Chrisalida	Northeast	69	0.1	Mylar balloon into conductor, sm.spot
2/7/2006	Hidden Valley	North Coast	69	0.1	Kite tail into insulators
9/9/2006	Grapevine	Ramona	69	5	Wire down, gun shot, 5 acre fire
10/27/2006	Boulder Creek	Mountain Empire	69	2	Hvy. wind, wire down, 2 acre fire
12/27/2006	Cmp. Pendleton	North Coast	230	3	Hvy. wind, wire down, 3 acre fire
6/14/2007	Sweetwater	Eastern	?	0.1	Mylar Balloon
6/25/2007	Ladera Ranch	Orange County	138?	0.1	Mylar Balloon suspected
6/30/2007	Stuart Mesa	North Coast	230	5	Static line failed in wind
7/6/2007	Carlsbad Plane Crash	North Coast	138	0.1	Plane crashed into tower & ignited fire
9/7/2007	Clairemont	Beach Cities	69	0.1	Bird contact
10/21/2007	Witch	Ramona	69	163,240	Under investigation.

2

3

4

5

As described in Appendix 2D of this Phase 2 testimony, SDG&E supplied the MGRA with data that allowed us to obtain the total length of their existing distribution and transmission networks. The measured ignition rate, in ignitions


⁶⁸ Obtained by cross-referencing to the SDG&E Outage History.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 per year per mile, can then be obtained by dividing the number of ignitions for a
 2 given line type with the length of line of that type within the SDG&E network.
 3 This has been done for SDG&E's data and is tabulated in Table 2D-3, also shown
 4 below:

Line Type	Length (mi)	Rate (yr ⁻¹ mi ⁻¹)	Low 90%CL	High 90%CL
Distribution	6757	2.96E-03	2.42E-03	3.59E-03
69 kV + 138 kV	1155	9.24E-04	3.16E-04	6.27E-03
230 kV	387	1.38E-03	2.48E-04	2.01E-02

5
 6 Once the rate was determined, a 90% confidence interval was obtained using
 7 the Poisson.rb calculator. The 90% confidence interval is defined as the region
 8 bounded on the low side by the rate that would have a 5% probability of
 9 producing the observed number of events or more, and on the high side by the rate
 10 that would have a 5% probability of producing the observed number of events or
 11 fewer. These results are shown graphically in figure 2D-1, shown below for
 12 convenience:



13
 14 The figure displays the historical ignition rate for distribution lines (purple
 15 diamond), 69 and 138 kV lines (yellow square), and 230 kV lines (red triangle). It

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 42 of 69

1 also shows the 90% confidence intervals as error bars. The most remarkable thing
2 about this plot is that it indicates that there is no statistical difference between
3 ignition rates for 69 kV lines and for 230 kV lines. In fact, the 230 kV lines have
4 had a greater ignition rate than 69 kV lines. While this excess is not statistically
5 significant, it certainly belies the claims made consistently by SDG&E that their
6 230 kV lines should not be expected to be a significant fire risk under high-wind
7 conditions.

8 The Draft EIR/EIS states that the engineering of 230 kV lines makes them less
9 subject to the types of faults that often cause fires on 69 kV lines.⁶⁹ It argues that
10 the primary ignition danger arising from the SPL will be due to human activity
11 and construction. The fire data analyzed by MGRA, on the other hand, *excludes*
12 human activity as a fire cause, with the reason being that the primary risk to life
13 and property posed by power lines is due to lines initiating fires during Santa Ana
14 wind conditions. Regardless of the supposed engineering superiority of 230 kV
15 transmission lines, they are still subject to design flaws, defects in construction
16 materials or workmanship, or insufficient or improper maintenance. While fire
17 rates from 230 kV lines *might* be less than those of other transmission lines based
18 on engineering considerations alone, this is not what the SDG&E fire data shows.
19 The final EIR/EIS needs to address this point and note that 230 kV lines have
20 caused ignitions in the SDG&E service area under windy conditions.

21

22 **Q. What conclusions can be reached from the SDG&E fire history data**
23 **regarding ignitions from 500 kV lines?**

24 **A.** Interestingly, the lack of initiated fires along the 500 kV SWPL route in
25 the 2004-2007 period does not put a significant constraint on the fire rate for 500
26 kV lines. SWPL has roughly 60 miles of exposure to flammable vegetation.⁷⁰
27 One observed fire would suggest a rate of $1 / 3.75\text{yr} * 60\text{mi} = 4.4\text{E-}03 \text{ yr}^{-1}\text{mi}^{-1}$.
28 The 90% confidence limit on a null observation is 2.3 times larger than this, or

⁶⁹ Draft EIR/EIS; pp. D.15-2 – D.15-4.

⁷⁰ Appendix 2C, Section 2C-2.1, attached file RouteAnalysis_SPLAlt.xls; tab SWPL_Hazard.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 43 of 69

1 1.02E-02 (.0102). This does not rule out a base fire rate that is equal to or even
2 exceeds the rate of other transmission lines. Even if SWPL were to have caused
3 no fires in its 20 year history, the 90% confidence level limit for fire rate would
4 still be 1.9E-03 (.0019), which still does not exclude the best estimates for 69 kV
5 and 230 kV fire rates. Hence there is no basis to conclude from the SDG&E fire
6 history data or historical data on SWPL that 500 kV transmission lines are any
7 more or less likely to ignite wildland fires than any other transmission line type.
8

9 **Q. Based upon SDG&E's historical fire rates, what is the predicted fire**
10 **recurrence time for the SPL route compared with alternative routes?**

11 **A.** Fire rate calculations based upon fire history for the proposed and
12 alternative routes is given in Table 2D-4, copied below. We use two hypotheses
13 for 500 kV lines 1) that they are 'fire safe' and do not contribute to fire risk (listed
14 in the table as '230 only'), and 2) that they have the same failure rate as the 69 kV
15 network (listed in the table as '230+500'). We include only the segment of the
16 500 kV path for each alternative that traverses flammable vegetation. In the case
17 of LEAPS, there are no 230 kV lines, however there are several miles of relocated
18 69 kV line that will have additional vegetation exposure. We treat this segment as
19 230 kV line in order to calculate the recurrence rate.
20
21

22 [Remainder of page left intentionally blank]

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 FIRE RECURRENCE PERIOD FOR ROUTES USING SDG&E HISTORY

Route	230 kV length (miles)	500 kV length (miles)	Recurs 230 only (yrs)	Recurs⁷¹ 230 + 500 (yrs)	Low 230 (yrs)	High 230 (yrs)	Low 230 +500 (yrs)	High 230 +500 (yrs)
SPL Proposed	50	20	14.5	11.4	80.6	4.6	53.4	3.9
Environmentally Superior North	32	20	22.7	16.0	125.9	7.2	70.1	5.5
Environmentally Superior South	20	62	36.3	11.8	201.5	11.5	40.7	4.6
SWPL	0	80	NA	13.5	NA	NA	39.5	5.9
LEAPS (230 kV really 69kV)	9	30	80.6	24.9	447.8	85.3	25.6	9.8

2

3

4

5

6

7

8

9

10

Under the hypothesis that 500 kV lines are substantially safer than 230 kV lines and produce fewer ignitions, the SPL and the ESNA would be expected to have the shortest recursion time (most frequent ignition). This is because the Southern Alternative (ESSA) consists of a 500 kV line for most of its traversal through the backcountry and only has a 230 kV segment for the last 20 miles of its length. LEAPS would be expected to have the longest recursion time (least frequent ignition) because the main route is all 500 kV, with only a short 69 kV segment being added along the Talega-Escondido line.

11

12

13

14

15

Under the assumption that 500 kV lines are no more or less likely to start fires than other transmission lines, the results are somewhat different. Under this assumption, the proposed SPL route and the ESSA are approximately the same, with an expected recurrence rate of 12 years. LEAPS once again has the longest recurrence period with 25 years.

⁷¹ Under the hypothesis that the fire rate for 500 kV is the same as the rate for 69 kV.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 45 of 69

1 These predicted fire start rates are for ignition only. The probability that a fire
2 will escape initial suppression efforts by fire fighters and become a significant fire
3 under Santa Ana conditions was calculated in Appendix F of the MGRA Phase 1
4 Direct Testimony to be approximately 36%.⁷² The predicted mean interval
5 between major fires can then be obtained by taking the values in the table above
6 and multiplying them by $1/.36 = 2.8$. Hence the predicted recurrence period for
7 large fires for SPL under the “safe 500 kV” hypothesis would be 40 years, and 32
8 years under the “same as other” hypothesis, which remains consistent with our
9 Phase 1 results. The statistical uncertainty is still quite large, though smaller than
10 it was during Phase 1 due to the increased statistics.

11
12 **Q. What are the impacts of potential system upgrades or expansions on**
13 **the number of fires expected during the project lifetime?**

14 **A.** A number of proposed system upgrades are discussed in the EIR/EIS, with
15 the proposed and most alternative routes being slotted for some type of upgrade.
16 The proposed SPL route for instance may require an upgrade in less than a decade
17 after its original construction: “At least four additional 230 kV future circuits may
18 be required after the two 230 kV circuits proposed as part of the SRPL[SPL].
19 Although this expansion may not be needed for decades, it is expected that two
20 additional 230 kV circuits are possible within the first decade following
21 completion of the Sunrise Powerlink. The most likely substation end points for
22 the additional 230 kV circuits are Sycamore Canyon, Penasquitos, Escondido,
23 Mission and Los Coches Substations.”⁷³

24 The route of these extra circuits would most likely be along the SPL (or
25 alternative) route: “From a planning perspective, SDG&E would, to the extent
26 possible, site additional lines in already disturbed corridors using existing ROWs.
27 As a result, at least one or two additional circuits could follow segments of the

⁷² MG-1; MGRA Phase 1 Direct Testimony; Appendix F; pp. 14-17.

⁷³ Draft EIR/EIS; Section B.2; p. B-5.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 proposed Sunrise Powerlink 230 kV transmission corridor, as described in Section
2 B.2.”⁷⁴

3 As likely expansions of the project, which could be considered “full build-out”
4 of the project, these impacts should be fully addressed in the EIR/EIS. While they
5 are discussed briefly throughout the Draft EIR/EIS, nowhere do potential
6 expansions encounter the same level of scrutiny as the main project or its
7 alternatives. This is a material factual deficiency in the Draft EIR/EIS, and should
8 be corrected in the final version.

9 In Appendix 2D, Section 2D-2.2⁷⁵, we address what the impact of system
10 expansion would have on the number of expected fires for the SPL project and
11 alternatives. To calculate the effect of expansion, we examine the total number of
12 expected fires over a forty year lifetime assuming 1) no expansion 2) construction
13 of two additional circuits after 10 years. These calculations are shown on the sheet
14 “Expansion” in File 2D-2 and the results are given in Table 2D-5, printed below:
15

16 NUMBER OF IGNITIONS EXPECTED IN 40 YEARS

No expansion	230 Fires	230+500 Fires	230 Low	230/500 Low	230 High	230/500 High
SPL	2.8	3.5	0.5	0.7	8.7	10.4
ESNA	1.8	2.5	0.3	0.6	5.6	7.2
ESSA	1.1	3.4	0.2	1.0	3.5	8.7
SWPL	0.0	3.0	0.0	1.0	0.0	6.7
LEAPS	0.5	1.6	0.1	0.5	1.6	4.1
10 yr Expansion						
SPL	4.8	5.6	0.9	1.1	15.2	16.9
ESNA	3.1	3.8	0.6	0.8	9.7	11.4
ESSA	1.9	4.2	0.3	1.1	6.1	11.3
SWPL	0.0	3.0	0.0	1.0	0.0	6.7
LEAPS	0.5	1.6	0.1	0.5	1.6	4.1

17
18 Several conclusions can be reached from the above data. One is that the
19 probable system expansions that would occur over the lifetime of the proposed

⁷⁴ Ibid.; Section B2.7; p. B-24.

⁷⁵ Appendix 2D, pp. 11-16.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 47 of 69

1 project increase the fire risk (shown above as number of fires expected to be
2 originated by the project over its lifetime). The fractional increase generally
3 depends on the length of the 230 kV segment. This is quite long for the proposed
4 SPL, and so an expansion to four circuits over 20 years would be expected to
5 almost *double* the number of expected fires. The Environmentally Superior
6 Southern Alternative (ESSA), on the other hand, has a much larger fraction of 500
7 kV transmission line along its path, and so the expansion impacts would be
8 somewhat less.

9 Accordingly, the ESSA route demonstrates the sensitivity of rate calculations
10 to assumptions made about the safety of 500 kV lines. The predicted number of
11 fires along ESSA varies by a factor between two and five based upon the
12 assumptions made regarding the safety of 500 kV lines.

13 Finally, it is clear that the statistical uncertainties involved make it difficult to
14 say with what the exact level of risk is. However, the observation of a second fire
15 in 2007 along the 230 kV transmission network has raised the predicted fire rate
16 for SPL, and additionally the likelihood of expansion would significantly increase
17 the level of risk. Between these two effects, the 90% confidence level lower limit
18 for the predicted number of fires along the proposed SPL route is approaching
19 1.0. *Consequently, it is possible to say that based upon extrapolation from*
20 *SDG&E fire history, and assuming future 230 kV system expansion, there is*
21 *roughly a 90% probability that the SPL would cause at least one fire during the*
22 *course of its projected 40 year lifetime.*

23
24 **5. MATERIAL FACTUAL DEFICIENCIES AND INACCURACIES IN THE**
25 **DRAFT EIR/EIS**

26
27 **Q. Does the Draft EIR/EIS make a reasonable attempt to address the**
28 **safety and environmental issues associated with wildland fire?**

29 **A.** The Draft EIR/EIS for the Sunrise Powerlink Proposal is a 7,000 page
30 document representing a tremendous expenditure of high quality talent and effort.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 48 of 69

1 Its thoroughness, which we understand is unprecedented for projects of this type,
2 should set a new, and we think appropriate, standard by which future projects
3 should be analyzed. Furthermore, the draft EIR/EIS contains more than 300 pages
4 of analysis related to wildland fire and power lines, and conducts a fire and fuels
5 analysis for every alternative to the project. This is highly commendable work.
6 However, the fire issues associated with the SPL are numerous, and the Draft
7 EIR/EIS does not adequately address all of them. Material factual deficiencies
8 and inaccuracies in the Draft EIR/EIS are addressed in detail in Appendix 2E,
9 submitted with this testimony.

10

11 **Q. What does the Draft EIR/EIS do well?**

12 **A.** As discussed in Appendix 2E, the following things were noted as
13 particular strengths of the Draft EIR/EIS: that every route and alternative was
14 analyzed with respect to wildland fire, that field data were collected to perform
15 DEIR analyses, that worst-case fire modeling was used to examine the impacts of
16 fire spread, and that an impact of the chosen routes on the effectiveness of
17 firefighting was performed. *We note that all transmission alternatives resulted*
18 *in Class I, immitigable impacts due to potential fire dangers, which is consistent*
19 *with MGRA Phase 1 and Phase 2 testimony, and that these impacts were used*
20 *in the determination of the environmentally superior alternatives. The Draft*
21 *EIR/EIS finds non-transmission alternatives preferable overall from an*
22 *environmental standpoint.*

23


24 **Q. What is the most serious material factual deficiency of the Draft**
25 **EIR/EIS?**

26 **A.** The treatment of the impact of the October 2007 fires, particularly with
27 respect to biology, is cursory. This is treated in section 2E-2.4 of Appendix 2E. A
28 related topic is the lack of a detailed route-specific treatment of “type conversion”
29 (the permanent loss of native habitat after extreme disturbance such as fires that

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 occur too frequently). This material factual deficiency is called out as a separate
2 issue in section 2E-2.3 of Appendix 2E.

3 This deficiency is particularly disturbing in the biological sections of the
4 DEIR, since impacts of major wildland fires in the past seven years have had a
5 tremendous impact on the vegetation and wildlife of the affected lands that many
6 of the alternate routes pass through. This is shown clearly in the figure below:



7
8 This figure shows the fires of 2002 and 2003 in dark blue cross-hatching, and
9 the fires of October 2007 in brown cross-hatching, superimposed on the proposed
10 and alternative routes. Areas affected by multiple fires are indicated by the
11 overlap of these two patterns, which creates diamond cross-hatching. The areas
12 that were burned once are highly sensitive to type conversion. It was for this
13 reason that MGRA argued in its Phase 1 Opening Brief that an exhaustive study
14 of type conversion and the sensitivity of lands be performed for and applied to

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 50 of 69

1 areas along the proposed route and any alternatives.⁷⁶ This was not done, and is a
2 major material factual deficiency in the DEIR.

3 Areas burned twice are at extreme risk, if they are in fact not already doomed.
4 As can be seen, both the northern and southern routes pass through such areas.
5 What is remarkable is that biological surveys have been performed the DEIR that
6 may have little relevance to the current status of the environment along the
7 proposed routes. There is no mention whatsoever in the Draft EIR of either the
8 Harris or Witch Creek fires in the biological sections of either the SPL route
9 analysis or of any of the alternative routes. Yet, for significant portions of the line,
10 the October 2007 fires may be the determining factor of the ecology of the areas
11 along the route for the coming years – and perhaps permanently.

12 *This situation can only be addressed properly by resurveying these areas in*
13 *the aftermath of the October 2007 fires to determine the risk posed to these*
14 *lands and their ecology by future power line fires and other impacts associated*
15 *with the lines.*

16
17 **Q. Are all routes adequately addressed in the Draft EIR/EIS?**

18 **A.** While the proposed and alternative routes get similar scrutiny in the Draft
19 EIR/EIS, the effect of route expansions is not given the same weight or level of
20 analysis, though they are disclosed and discussed. This constitutes a material
21 factual deficiency in the Draft EIR.

22 The topic of expansion of the proposed project has been addressed at the
23 direction of the July 24, 2007 ruling by Commissioner Grueneich, in which she
24 stated that “the Commission must thoughtfully consider how this potential future
25 expansion should be analyzed in the EIR/EIS”⁷⁷, and cites and quotes from the
26 case *Laurel Heights Improvement Ass’n v. Regents of Univ. of Cal.* (1998): “All

⁷⁶ MGRA; Phase 1 Opening Brief; A.06-08-010; p. 8.

⁷⁷ California Public Utilities Commission; Assigned Commissioner’s Ruling Addressing Newly Disclosed Environmental Information; A.06-08-010; July 24, 2007; p. 6.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 51 of 69

1 phases of a project must be considered when evaluating its impact on the
2 environment.”⁷⁸

3 The lack of full scrutiny of the expansion routes for the proposed and
4 alternative routes in the Draft EIR/EIS is excused because “approval of the SRPL
5 would not result in automatic approval of the potential future expansions to the
6 SRPL and all future 230 or 500 kV lines would require new applications by
7 SDG&E, followed by preparation of project-level environment documents and
8 separate approvals from the CPUC prior to permitting and construction.”⁷⁹

9 However, this reasoning leads to insufficient scrutiny of all phases of the project
10 and would be true for expansions which could not be considered a phase of the
11 project.

12 Yet for the 230 kV expansions in particular, there is a very strong case to be
13 made that these expansions should be considered “full build-out” of the project
14 and therefore need to be fully analyzed within the scope of the EIR/EIS. The 500
15 kV transmission line that would form the backbone of the SPL transmission
16 infrastructure has twice the capacity of the transmission line that would feed from
17 it at the proposed Central Substation.⁸⁰ The DEIR notes that adding additional
18 circuits might be possible within 10 years after completion of the primary route.
19 The routes for these additional circuits, if approved, would most likely follow the
20 ROW already disturbed by construction of the SPL or other routes: “From a
21 planning perspective, SDG&E would, to the extent possible, site additional lines
22 in already disturbed corridors using existing ROWs. As a result, at least one or
23 two additional circuits could follow segments of the proposed Sunrise Powerlink
24 230 kV transmission corridor...”⁸¹

⁷⁸ *Laurel Heights Improvement Ass’n v. Regents of Univ. of Cal.* (1988) 47 Cal.3d at 396; 14 Cal. Code Regs. Sec. 15126

⁷⁹ Draft EIR/EIS; Section B.2; p. B-5.

⁸⁰ *Ibid.* The 500 kV line can feed up to four 230 kV circuits. Only two are proposed for the SPL and for alternative routes.

⁸¹ *Ibid.*; Sec. B.2.7.1; p. B-24.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 52 of 69

1 Fire would not be the only consideration. Visual impacts would be greater with
2 230 kV build-out, as would other potential impacts under CEQA/NEPA. These
3 must be fully addressed in order to remedy this material factual deficiency in the
4 Draft EIR/EIS. The impacts of these expansions on fire risks are addressed
5 elsewhere in this testimony, and derive from Appendix 2D.⁸²

6 The 230 kV expansions are easily foreseeable expansions to the project or its
7 alternatives, and would never themselves occur without the project being in place.
8 Hence, they should be viewed as part of the project and fully analyzed as part of
9 the final EIR/EIS.

10

11 **Q. Are there methodological material factual inaccuracies and**
12 **deficiencies in the Draft EIR/EIS?**

13 **A.** Yes, and we discuss two in particular. One easily remediable deficiency is
14 to adopt a more quantitative approach for the results of burn probability modeling
15 and wildfire containment conflict modeling, so that the results can be easily
16 compared for different routes in a quantitative way. This is discussed in Section
17 2E-2.2 of Appendix E.

18 More significant is the bias expected to be present in vegetation surveys
19 conducted shortly after a fire, which is addressed in Section 2E-3.2 of Appendix
20 E. This was a major issue raised in the MGRA Phase 1 direct testimony – that the
21 areas burned in the 2002 and 2003 fires if measured now would show fuel loads
22 that were significantly less than the typical load that would be expected during the
23 SPL lifetime.⁸³ This was confirmed by SDG&E’s witness Hal Mortier during
24 cross-examination⁸⁴ and constitutes a material factual inaccuracy.

⁸² Appendix 2D, p. 14.

⁸³ MG-1; Appendix D; Section 2.1.5; p. 10.

⁸⁴ Cross Examination of witness Mortier; Public Utilities Commission, State of California; A0608010; July 17, 2007; p.1007.

Exhibit MG – 10; CDF Fire Threat - Pre-Cedar (2003)/Pines(2002) Fires;

Exhibit MG – 11; CDF Fire Threat - Post Cedar (2003)/Pines (2002) Fires;

Exhibit MG – 12; CDF Fire 2003 - Pre-Cedar/Pines Enlarged "Sunrise" Northern Loop

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 53 of 69

1 This same bias would be expected to appear in the site surveys performed by
2 the Draft EIR/EIS.⁸⁵ This should be adjusted for, and maps regenerated for areas
3 of the route affected by recent fires. If this has already been taken into account in
4 the “burn probability maps”, then the exact method used to adjust for the bias
5 should be stated in the final Draft EIR/EIS.

6

7 **Q. Are there material factual inaccuracies or deficiencies in mitigation**
8 **measures proposed by the Draft EIR/EIS?**

9 **A.** As discussed in Section 2E-2.5 of Appendix 2E, the proposal for a
10 vegetation management fund, while innovative, suffers from two shortcomings.
11 The first is that vegetation management is not an adequate measure for protecting
12 structures (a fact acknowledged in the Draft EIR/EIS). While it is one component
13 of structure protection, vegetation management does little to protect against
14 secondary fires started by wind-driven embers and firebrands, which have been
15 shown in several studies to be the primary means by which structures are ignited
16 and destroyed fires.^{86,87,88} Only measures that prevent ember (or firebrand)
17 ignitions are effective in protecting homes.^{89,90}

18 The second problem with this approach is the tremendous size of catastrophic
19 wildland fires. In the Witch Fire, for instance, the distance from the origin of the
20 fire east of Ramona to its western terminus near Del Mar is roughly 29 miles.
21 Along its north/south axis, its maximum extent is 23 miles. This perimeter is
22 much larger than those considered in the Draft EIR/EIS, and contains a substantial

⁸⁵ Draft EIR/EIS, Appendix 3, Sections 3A, 3B.

⁸⁶ Ramsay, G.C., McArthur, N.A. & Dowling, V.P.; Preliminary results from an examination of house survival in the 16 February 1983 bushfires in Australia; Fire and Materials, 11 (1987) 49.

⁸⁷ FOOTE, E.I.D.; 1994; Structure survival on the 1990 Santa Barbara “Paint” fire: A retrospective study of urban-wildland interface fire hazard mitigation factors. MS thesis, University of California at Berkeley.

⁸⁸ Cohen, Jack D. 2000. Preventing disaster: home ignitability in the wildland-urban interface. Journal of Forestry 98(3): 15-21.

⁸⁹ Mitchell, Joseph W.; Wind-enabled ember dousing; Fire Safety Journal; Volume 41, Issue 6, September 2006, Pages 444-458.

⁹⁰ Mitchell, Joseph W. and Oren Patashnik; Firebrand Protection as the Key Design Element for Structure Survival during Catastrophic Wildland Fires; Fire and Materials 2007, San Francisco, Jan. 2007. Available at: http://www.mbartek.com/FM07_FirebrandsWildfires_1.1F.pdf

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 54 of 69

1 number of homes that would not be considered for mitigation under the proposed
2 plan. Clearly, it is not possible to protect all homeowners in the areas potentially
3 affected by power line fires. Hence, even if the utility were to make payments to
4 a mitigation fund that ended up saving more homes overall than were lost in the
5 fire, it could still be liable for property damage due to the fire. This proposal is
6 deficient as mitigation. These shortcomings need to be alleviated or disclosed in
7 the final EIR/EIS.

8

9 **Q. Were any incorrect conclusions reached in the Draft EIR/EIS?**

10 **A.** Yes. The overview of power line fires given in the draft EIR/EIS comes to
11 one conclusion that is not supported by data, and which is contradicted by
12 information presented in this testimony, thereby constituting a material factual
13 inaccuracy. We address this in section 2E-3.1 in Appendix 2E of this testimony.
14 The Draft EIR/EIS states that: “There is a public perception that all power lines
15 can be a direct cause of wildfire ignitions, but power line-caused fires are much
16 more prevalent for distribution and lower-voltage transmission lines compared
17 with higher-voltage transmission lines such as the Proposed Project.”⁹¹ The Draft
18 EIR/EIS also states that “The primary ignition threats associated with higher-
19 voltage transmission lines like the Proposed Project are indirect, consisting of
20 human-caused accidents during construction and maintenance activities and as a
21 result of increased access to wildlands.”⁹²

22 The testimony given in Appendix 2D of this testimony contradicts this claim,
23 which is based upon the supposedly superior engineering characteristics of high
24 voltage transmission lines, rather than in any quantitative study of fire rates. The
25 problem with the approach taken by the Draft EIR/EIS (and by SDG&E in
26 equivalent statements regarding the line) is that this analysis ignores the fact the
27 defects in design, engineering, manufacturing, construction, or due to improper or
28 inadequate maintenance can cause failures. The SDG&E network is tremendously

⁹¹ Draft EIR/EIS; Section D.15; p. 15-3.

⁹² Ibid.; p. 15-4.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 55 of 69

1 large and complex, and consists of a huge number of individual components,
2 many of which could be the cause of a fire were they to fail mechanically or
3 electrically.

4 Protective measures such as automatic fault detection and shut-off requires that
5 the fault occur before the shut-off can take place, which can take between 1/60
6 and 3/60 of a second. However, a serious failure on a 230 kV or 500 kV line can
7 release significant heat energy and create hot fragments capable of igniting
8 vegetation in the time it takes to de-energize the line, a fact not contested by
9 SDG&E: “SDG&E makes no assertion that a circuit breaker which de-energizes
10 in 0.1 second will prevent arcing in the event of a short circuit or other line fault
11 in 230 kV or 500 kV lines”.⁹³

12 Engineering considerations aside, the fact that 230 kV lines have started two
13 fires due to component failure and wind problems during the last two years is
14 conclusive proof that this type of event *can and does* happen. Furthermore, the
15 calculations put forward in Appendix 2D demonstrate that there is no measurably
16 significant difference between the fire rates for 69 kV and 230 kV transmission
17 lines.

18 It would be proper to either mention this fact in the Draft EIR/EIS, or to
19 remove the assertion that the primary expected cause of fires due to the lines are
20 expected to be due to construction and human access, which implies that
21 transmission lines left to themselves are relatively safe. This is an extremely
22 important point, because fires due to line faults in high winds are over ten times⁹⁴
23 more likely to develop into large fires than fires started by construction (which
24 can be curtailed during red-flag warning days) and access by people along service
25 roads. MGRA’s extreme concern regarding power line fires is focused on the
26 issue of catastrophic fires and wind-initiated faults or failures because these fires
27 are the most devastating to people, property and the environment.

⁹³ SDG&E’S 1/12/07 RESPONSE TO MGRA Data Request No. 1; MGRA-9.

⁹⁴ This can be derived from MG-1; MGRA Phase 1 Direct Testimony; Appendix F. The success of firefighting initial attack is generally 98%. This drops to 64% when there are severe winds near the fire’s point of origin. The ratio of failed initial attack is 36% / 2% is 18 times.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 56 of 69

1 **Q. Were all topics raised by the MGRA and requested for inclusion dealt**
2 **with in the Draft EIR/EIS?**

3 **A. No.** In the MGRA’s Phase 1 Opening Brief, recommendations 11 to 13
4 deal with the necessity of handling wind and its relation to wildland fire.⁹⁵ In
5 particular, it requested that Santa Ana conditions be analyzed for the area under
6 study using both best-available weather modeling and also the data from local
7 weather stations.

8 None of this analysis was performed. Only SDG&E, in its response to MGRA
9 data request number six⁹⁶, provides any weather analysis data at all. This has
10 effectively gone unchallenged and unexamined by the Commission, but it is of
11 critical importance for the safety of the public. *The omission of wind analysis is a*
12 *material factual deficiency in the Draft EIR/EIS, which unless addressed will*
13 *result in an incomplete and flawed report, as the MGRA critique of the SDG&E*
14 *analysis in Appendix G shows.*

15

16 **6. CRITIQUE OF SDG&E WIND DATA AND ANALYSIS**

17

18 **Q. Is the SDG&E study of wind, conducted for purposes of engineering**
19 **the line, adequate to protect against wildland fire?**

20 **A. No.** This study does not appear be targeted at the effects of Santa Ana
21 winds, which are the most serious and fire-prone weather conditions expected for
22 the area affected by the proposed SPL. The analysis that supports this conclusion
23 can be found in Appendix 2G of this testimony.

24

25 **Q. What data and analysis lead to the conclusion that the SDG&E study**
26 **does not adequately address Santa Ana winds?**

27 **A. SDG&E** cites and notes meteorological sources which describe the
28 conditions that are associated with extreme wind events. Among the conditions

⁹⁵ MGRA Phase 1 Opening Brief; pp. 7-8.

⁹⁶ SDG&E; Response to MGRA Data Request #6. <http://www.sdge.com/sunrisepowerlink/discovery.shtml>

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 57 of 69

1 that are explicitly mentioned as being associated with high winds are canyons or
2 valleys that are aligned along the direction of prevailing winds and additionally
3 downhill wind flow forced by strong atmospheric pressure gradients. In the
4 SDG&E study, these criteria are deemed to be relevant to Grapevine Canyon,
5 which contains a segment of the proposed SPL route. Grapevine Canyon trends
6 east-southeast downhill from the coastal range, making it nearly perpendicular to
7 prevailing Santa Ana winds. Additionally, the slope is uphill to the west, opposite
8 to that associated with strong Santa Ana wind conditions. Nevertheless, SDG&E
9 has designed this segment of line with very conservative wind gust design criteria,
10 requiring that the line endure wind gusts up to 146 mph. This would only be
11 appropriate for winds coming in from the west. While such winds could
12 potentially occur, and the design requirements are probably appropriate, the “wet
13 storm” that they would be associated with would not likely be the start of a
14 catastrophic power line fire if a component failure occurred.

15
16 **Q. What design criteria has SDG&E applied in areas of Santa Ana wind**
17 **hazard?**

18 **A.** Areas from the western terminus of the line to east of Ramona are
19 assumed not to have wind gusts any stronger than 56 mph. From the area east of
20 Ramona east to Grapevine Canyon the maximum wind gust speed to be designed
21 for would be 68 mph.

22
23 **Q. What does SDG&E base these design criteria on?**

24 **A.** The criteria are based upon weather station data. The majority of the 56
25 mph segment is based on historical wind data from Lindbergh Field. The
26 remainder of the 56 mph segment is based on wind data from Ramona Airport.
27 For the 68 mph segment, the wind gust design criterion was determined by data
28 from the Campo weather station. The application of these criteria to the route is

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 58 of 69

1 displayed in the map provided by SDG&E along with its data request, attached as
2 File 2G-2⁹⁷.

3

4 **Q. Why are these choices of weather station inappropriate for Santa Ana**
5 **conditions?**

6 **A.** Use of a coastal weather station, such as Lindbergh Field, for determining
7 Santa Ana gust criteria is inappropriate. The distribution of Santa Ana winds is
8 determined as a result of a struggle between the Santa Ana winds and the daily
9 on-shore flow of marine air, coupled with interactions with the local
10 topography^{98,99,100}. This interaction, along with a graphic depicting the segments
11 of the proposed SPL with different design criteria (as per the delineations
12 provided in File 2G-2), is shown in Figure 2G-1, reproduced below:

13

14


[Remainder of page left blank]

⁹⁷ Appendix 2G; p. 3; SDGE_MGRA49_map.pdf

⁹⁸ Fosberg, Michael A., O'Dell, Clyde A., and Schroeder, Mark J. 1966. Some characteristics of the three-dimensional structure of Santa Ana winds. Berkeley, Calif., Pacific SW. Forest & Range Exp. Sta. 35 pp., illus. (U. S. Forest Serv. Res. Paper PSW-30)

⁹⁹ Raphael, M. N.; The Santa Ana Winds of California; Earth Interactions; Volume 7 (2003) p. 1-13.

¹⁰⁰ Sommers, William T.; LFM Forecast Variables Related to Santa Ana Wind Occurrences; Monthly Weather Review; September, 1978; v. 106, pp. 1307-1316.



1
2
3
4
5
6
7
8
9
10
11
12
13
14

The strength of on-shore (thin blue arrows) winds versus the Santa Ana pressure gradient (thick blue arrows) determines how far from the mountains that Santa Ana conditions can extend. Where the winds line up with downslope topographical features such as valleys they can be significantly accelerated. These downhill gradients are depicted by the dashed black arrows in the figure. The green circles represent weather stations. Those used in MGRA analysis are in bold-face, while those used only by SDG&E such as Lindbergh Field (LBG) and Ramona Airport (RAM) are in italics. Note that many of the downslope areas are oriented in a roughly parallel direction to the Santa Ana winds. This conforms to SDG&E's expectation for high-wind areas: "*Winds can be strong and gusty near the mouths of canyons oriented parallel to the direction of airflow. Funneling of airflow through mountain passes and along deeper valleys can cause unusually high wind speeds... valleys with persistent down slope winds*

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 60 of 69

1 *associated with strong pressure gradients.*”¹⁰¹ However, contrary to this
2 assessment, the western regions were not treated as high wind areas. In the region
3 with hazardous vegetation, only the Grapevine Canyon segment was designed for
4 high winds.

5

6 **Q. Does the Grapevine Canyon segment, designed for 146 mph winds,**
7 **experience strong Santa Ana events?**

8 **A.** No, not compared to nearby weather stations on western slopes. Wind gust
9 data taken from the Ranchita weather station shows that during Santa Ana events
10 the winds actually can be calmer than they were prior to or after the event. This is
11 shown in Figure 2G-3, which shows ten days of data from the Ranchita (RCH)
12 RAWS weather station.¹⁰² This can be compared with Figure 2G-4, which depicts
13 the same data collection period from a nearby weather station in Julian (JLN), and
14 which shows strong, gusting Santa Ana winds.¹⁰³

15

16 **Q. What criteria were used for determining the design criteria for the**
17 **Grapevine Canyon segment?**

18 **A.** SDG&E used weather data from the Beaumont Canyon weather station in
19 Riverside County. This is used as a “worst case” weather station, being situated in
20 the San Gorgonio Pass and being known for very strong wind conditions. This
21 was deemed appropriate because Grapevine Canyon is a steeply sloping mountain
22 canyon, and if its direction was aligned with a strong wind – particularly one from
23 the west-northwest so that the flow was downhill – the wind could experience
24 strong acceleration and reach extreme wind speeds.

25

26

27

¹⁰¹ SDG&E; Response to MGRA Data Request #6. <http://www.sdge.com/sunrisepowerlink/discovery.shtml>

¹⁰² Appendix 2G; p. 11.

¹⁰³ Appendix 2G; p. 10.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 62 of 69

1 Ramona. The Ramona Airport lies near the western end of the broad Santa Maria
2 Valley, and is a poor representative of the steep canyon lands that the SPL route
3 traverses through the area. The “worst-case” Beaumont station is included for
4 comparison.

5 We note that the “coastal effect” is very strong. Data from the La Jolla (LJ2)
6 station indicate a strong suppression of Santa Ana conditions. We can deduce that
7 the Lindbergh Field (LBG) station would be experiencing similar conditions.
8 Hence, it is inappropriate to use it as a design reference for any portion of the line
9 when designing for Santa Ana wind events.

10 Another thing to be noted is the strong consistency between the Potrero (POT),
11 Descanso (DSC), Julian (JLN), and Campo (CMP) stations. While these vary
12 from event to event as far as which encountered the strongest gust, the maximum
13 gust speeds for these stations are usually quite close together, and this should be
14 taken to mean that they are good representatives of the regions high on the
15 western slopes of the coastal range, and also that Santa Ana winds effect the
16 entire region and are not an entirely local phenomenon.

17 The weakening of the Santa Ana event as it approaches the coast can be seen
18 first at Goose Valley (GOS), which has slightly lower values than the maximum
19 stations, and then at Ammo Dump (AMO), which is in northeast San Diego
20 County and still closer to the coast.

21 It would therefore be appropriate to extend conservative design criteria into
22 any region where the Campo (CMP) weather station data would be considered
23 appropriate, assuming that there are valleys tending downslope to the west in the
24 area being reviewed.

25

26 **Q. Have the wind gust limits proposed by SDG&E for maximum**
27 **expected 50-year wind load on the SPL been approached or exceeded by**
28 **Santa Ana Winds?**

29 A. Yes. The wind gust speed at Goose Valley (GOS) in October 2007 was 54
30 mph, only two mph short of the maximum gust design criteria. The SPL route to

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 63 of 69

1 the east would have been expected to encounter even stronger winds, and there is
2 a good chance that the design criteria would have been exceeded. Likewise, the
3 Potrero (POT) station recorded a maximum gust speed of 70 mph, and this would
4 also have exceeded the 68 mph wind gust criterion put in place for Campo.

5 However, the Ranchita (RCH) station, near the SPL segment designed for 146
6 mph gusts, encountered winds that were similar to the coastal winds measured in
7 La Jolla (LJ2).

8

9 **Q. Was the Beaumont station a plausible “worst-case” weather station?**

10 **A.** Yes, the Beaumont (BMT) station is a plausible “worst-case” weather
11 station, having recorded the maximum wind gust value measured in three (but
12 only three) of the six events. Notably, though, it did *not* exceed the wind speed
13 measured at the Potrero station during the October 2007 Santa Ana event, and
14 both Descanso and Campo stations clocked speeds of only 5 mph less than
15 Beaumont. This suggests that it may even be appropriate to use the Beaumont
16 weather station data for line segments for which the Campo weather station is
17 now being used. Beaumont is also preferable from an analysis standpoint because
18 it has a much longer data history than the other stations, as can be seen in the logs
19 attached to this testimony¹⁰⁴.

20

21 **Q. Exactly how are the maximum wind gust speed design values shown**
22 **in the SDG&E map derived from the weather data?**

23 **A.** This is not clear, because the approach taken by SDG&E is inconsistent.
24 According to an example calculation provided by SDG&E¹⁰⁵, the maximum
25 design wind gust load is determined by estimating the 100 year maximum wind
26 speed using statistical tools, and then multiplying it by a factor of 1.6 “gust
27 factor”. However, this approach has not been consistently applied. This can be

¹⁰⁴ Appendix 2G; File 2G-1; WindHistory.xls; p. 3.

¹⁰⁵ SDG&E Response; MGRA-48.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 seen by examining the correlation of the map and the calculations provided in the
2 MGRA Data Request #6 and shown in the table below:

3
4 **COMPARISON OF SDG&E WIND GUST MAP AND ANALYSIS**

Segment West	Segment East	Max Gust mph	Station	50 y Wind mph	50 y Gust mph	100 y Wind mph	100 y Gust mph
Del Mar	Ramona	56	LBG	50.0	80.0	55.3	88.4
Ramona	E. Ramona	56	RAM	42.8	68.5	45.3	72.5
E. Ramona	Grapevine	68	CMP	54.3	86.9	57.7	92.3
Grapevine	Desert	146	BMT	75.6	121.0	91.4	146.2
Desert	Desert	103	El Centro	60.5	96.8	64.6	103.4

5
6 One of the most notable problems in the analysis shown in the table above is
7 that the method detailed by SDG&E indicates that five different segments of the
8 line were independently treated between the desert and the western end of the
9 line, whereas the map provided to illustrate this shows only four segments. It
10 appears that the 56 mph segment represents a merger of the first two segments
11 (LBG and RAM) in the SDG&E analysis description.

12 In the data request, the design gust factor was defined as being obtained by
13 taking the 100 year wind speed and multiplying it by a “gust factor” of 1.6. As
14 can be seen in the table, this was applied correctly for the Desert and Grapevine
15 Canyon segments of the line. However, it is not at all clear how the 56 mph and
16 68 mph gust values were obtained. It would appear that for the western segment it
17 is possible that the 100 year wind speed and not 100 year gust speed was used.
18 For the sections from Ramona to Grapevine canyon, there is no plausible
19 explanation of how the value of 68 mph listed on the map was obtained.

20 If the map provided by SDG&E is simply inaccurate, it should be corrected
21 and the correct values for wind gusts applied, and the map re-issued to the MGRA

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 65 of 69

1 and the Commission. *If, however, the SDG&E map accurately represents the*
2 *planned engineering design limits for the SPL, this represents a major and*
3 *potentially catastrophic under-engineering of the project.* New construction
4 costs would need to be developed by SDG&E and provided for inclusion in Phase
5 2 cost/benefit analysis.

6

7 **Q. Do any other data support the assertion that the western segment of**
8 **the line requires a more conservative design?**

9 **A.** Yes, data from the National Digital Forecast Database (NDFD) can be
10 used to support the assertion that Santa Ana wind intensities are much greater on
11 the western portion of the line. These are recorded forecasts that show predicted
12 wind gust intensities for a coarse grid of geographic cells. While they are not fine-
13 grained enough to handle the effects of small-scale topography, they show general
14 trends. A plot from the October 2007 Santa Ana event, representing the forecast
15 for a period two hours prior to the start of the Witch Fire, is shown in Figure 2G-
16 4, shown again below:


17

18

[Remainder of page is left blank]

19

PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010




1
2
3
4
5
6
7
8
9
10
11

As is quite clear, the most intense winds would have affected only those portions of the line designed for 56 mph and 68 mph wind gusts.

Q. Do conditions exist on the western slopes of the mountains that would merit the application of conservative design standards?

A. Yes. There are a number of valleys and canyons along or near the proposed SPL route that trend downhill from the northeast to the southwest which could align with Santa Ana winds and cause “funneling” and acceleration of the wind speeds. These are shown in Figure 2G-5, also attached below:

PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010



1
2
3
4
5
6
7
8
9
10
11
12

Some of the canyons that could potentially align with Santa Ana winds from the northeast quadrant are indicated by dashed arrows. Among the valleys and canyons that the SPL route crosses, approaches or follows are Bloomdale Creek, Santa Ysabel Creek, the San Diego River, Kimball Valley, and San Vicente Creek.

Also indicated on the map are Cedar Creek, starting point of the Cedar Fire, which is California's largest historical fire, and Witch Creek, starting point of the Witch Fire, which is California's fourth largest historical fire. That these are only about five miles apart is not fully coincidental – this area is well known by locals and firefighters to be subject to some of San Diego's worst Santa Ana wind conditions. The Witch Fire started in or near the ROW of the 69 kV transmission

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

1 line that is planned for consolidation with the ROW of the Sunrise Powerlink
2 project and follows the same path through the area¹⁰⁶.

3

4 **Q. What return time for catastrophic wind events should be chosen to**
5 **protect the public?**

6 **A.** SDG&E studied 50 and 100 year return times as part of its standard
7 analysis. However, as shown in Table 2G-2, reproduced below, these are not fully
8 adequate.

Return Period (years)	Expected Occurrences	Probability ≥ 1 event
50	0.8	55%
100	0.4	33%
200	0.2	18%
300	0.13	12%

9

10 The probability column shows the calculated probability that the wind gusts
11 will exceed the design criteria during the forty year lifetime proposed for the
12 project. Given that component failures in the wind may lead to ignition and rapid
13 fire growth, with massive loss of property, life, and environment (as recently
14 occurred in the Witch Fire) it is critical that the line be designed in such a way
15 that recurrence of a wind event that approaches the designed maximum is very
16 small. This criterion would only be achieved by accepting design criteria that
17 assume at least 200 and preferably 300 year recurrence times.

18

19

20

¹⁰⁶ San Diego Gas and Electric Company; Sunrise Powerlink Transmission Project; Application for Certificate of Public Convenience and Necessity; Proponent's Environmental Assessment; August 6, 2006; Figure 2.3-1E, Figure 2.3-1E, Table 3.4-2.

**PHASE 2 DIRECT TESTIMONY OF
THE MUSSEY GRADE ROAD ALLIANCE
A.06-08-010**

Page 69 of 69

1 **Q. What impacts would these mitigation measures have on the proposed**
2 **SPL project?**

3 **A. We would recommend applying the more stringent “Beaumont” design**
4 criteria to SPL route areas on the western slopes of the coastal range. We would
5 also recommend application of 300 year recurrence times due to the potentially
6 catastrophic consequences of line failures under high wind conditions. A number
7 of measures that can be taken to comply with GO 95 are listed in the response to
8 MGRA Data Request #6¹⁰⁷. The extra cost of adding these engineering
9 enhancements to the line in areas at-risk should be included as potential
10 mitigation in Phase 2 testimony and added to the total cost of the project as part of
11 the overall cost/benefit analysis. Additionally, these engineering enhancements
12 might have significant visual impacts, and these would need to be fully disclosed
13 and analyzed as part of the Final EIR/EIS.

14

15 **Q. Does this conclude your testimony for MGRA?**

16 **A. Yes, this concludes my portion of the MGRA testimony.**

¹⁰⁷ Sunrise Powerlink Project; SDG&E’s 3/3/08 Responses to MGRA Data Request No. 6; MGRA-51.